

Date: April 18, 2017

Project: Kipnuk Bulk Fuel and Power System
Upgrades

Solicitation No.: 17068

Notice to Bidders Two

TO ALL PLANHOLDERS:

Enclosed is an informational Notice to Bidders – no acknowledgement is required.

Sincerely,

Rich Wooten, CDT, CPSM
Contracting Officer

NOTICE TO BIDDERS	Page Number 1	No. of Pages 1
	Date Issued: April 18, 2017	
Issuing Office Rich Wooten, CDT, CPSM Alaska Energy Authority 813 W Northern Lights Blvd Anchorage, AK 99503 Phone: (907) 771-3019 Fax: (907) 771-3044	Previous Addenda Issued Addendum One, April 6, 2017 Addendum Two, April 13, 2017	
Project: Kipnuk Bulk Fuel and Power System Upgrades Solicitation No.: 17068	Date and Hour Quotes Due: April 20, 2017 at 2:00 p.m., prevailing Anchorage time.	

This is an informational Notice to Bidders, not an addendum; therefore no acknowledgement is required.

- 1) **Q:** Section 01 45 00 Quality Control – The documents specify that the dedicated field QC Manager may also serve as the SSHO. Can this person also serve as the Project Superintendent or maintain any other duties?

A: Per Specification Section 01 45 00; 1.04; H – the Quality Control Manager may also serve as site safety officer. This person may not serve as the Project Superintendent or maintain any other duties, unless those duties are providing qualified, independent inspection services. If the QC Manager is to also provide inspection services, then he must have an independent relationship with the Contractor.

- 2) **Q:** Section 09 97 13 Coatings – Can the independent NACE Certified Coating Inspector perform other onsite duties?

A: Per Specification Section 09 97 13.23; 1.05; B – Inspection shall include an independent NACE Certified Coating Inspector. This person may not perform any other onsite duties, with exception of performance of other qualified independent quality control or safety services, such as QC Manager / site safety officer, as long as these services all remain independent of the Contractor.

Note: Any reference to NACE Certified Inspector in the Contract Documents implies that the inspector is a Level 3 NACE Certified Coating Inspector, or that this inspection is performed by a NACE Level 1 or Level 2 Coating Inspector under the direct supervision of a NACE Level 3 Inspector in accordance the NACE Coating Inspector Program. If a NACE Level 1 or Level 2 Coating Inspector working under the direct supervision of a NACE Level 3 Certified Coating Inspector is used to satisfy the coating inspection requirement for this project, the Level 3 inspector must work for the same Company as the Level 1 or Level 2 inspector.

END OF NOTICE TO BIDDERS