

**ALASKA ENERGY AUTHORITY
VILLAGE POWER SYSTEM ASSESSMENT**

Community: Port Alsworth
Evaluation Date: Sept 8, 2012 Time Started 8:00a Completed 3:00p
Evaluator(s): Mike Dunn

*** Indicates that only one from the group shall be chosen. Otherwise choose all that apply**

Powerhouse Building

Site Location

- ☒ Site suitable for powerhouse
- ☐ < 100 feet from a public well
- ☐ < 25 feet from an eroding bank or beach, or in a flood plain

*** Foundation**

- ☒ Powerhouse on acceptable foundation (pad & post, piling, concrete, etc.)
- ☐ Powerhouse directly on gravel pad or light timbers (raised timbers, on permeable gravel)
- ☐ Powerhouse directly on tundra or natural soils (no foundation)
- ☐ Powerhouse leaning considerably or unstable foundations (seismic hazard)

*** Flooring**

- ☒ Welded steel deck plate or concrete (sealed)
- ☐ Steel deck plate or concrete (unsealed)
- ☐ Wood (sealed or painted)
- ☐ Wood (non-sealed or bare)

*** Interior Walls**

- ☐ Concrete or metal skin
- ☐ Fiberglass reinforced paneling (FRP)
- ☒ Gypsum board
- ☐ Wood (painted or sealed)
- ☐ Wood (non-painted or bare)

*** Exterior Walls**

- ☐ Concrete or metal siding
- ☒ Wood (painted or sealed)
- ☐ Wood (non-painted or bare)

* Roof Penetration

- ☐ None
- ☐ Properly installed (rain tight)
- ☒ Minor leaks (repairable)
- ☐ Major leaks (not repairable)

* Ventilation

- ☐ Proper ventilation (air intake & exhaust fans, louvers & hoods)
- ☒ Adequate ventilation (air intake & exhaust fans)
- ☐ Minimum ventilation (air intake)
- ☐ No ventilation (doors or windows have to be left open)

* Lighting

- ☐ Excellent lighting
- ☒ Adequate lighting
- ☐ Poor lighting
- ☐ No lighting

Security

- ☐ Powerhouse fenced in & door locks
- ☒ Door locks
- ☐ No fence
- ☐ No door locks

Generator Equipment and Installation

Diesel Engines

	Unit #1	Unit #2	Unit #3	Unit #4	Unit # 5
kW	125kW	154kW	187kW	_____	_____
Hours of Operation	39859	15278	1593	_____	_____

* Generator Condition

	Unit #1	Unit #2	Unit #3	Unit #4	Unit #5
Good, like new	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Fair	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Poor, guards/covers missing	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

Load Sizing

- ☒ Properly sized generation to meet the community loads
- ☐ Undersized generation to meet the community loads
- ☐ Oversized generation to meet the community loads

* Load Balance

- ☐ <10% Imbalance
- ☒ 10% to 25% Imbalance
- ☐ >25% Imbalance

* Control Switchgear

- ☐ Fully automatic synchronizing switchgear
- ☒ Semi-automatic synchronizing switchgear #1/#2 Auto, #3 is all Manual
- ☐ Manually synchronizing switchgear
- ☐ Manual transfer switches
- ☐ Manual mounted breakers

* Electrical

- ☒ Wiring appears appropriate
- ☐ Exposed wiring, improper grounding, missing covers etc.

* Fuel System Inside Powerhouse

- ☐ Welded piping
- ☒ Welded & threaded piping
- ☐ Threaded piping
- ☐ Rubber hose

Fuel System Appurtenances

- ☐ No day-tank
- ☐ Additional for active leaks

Totalizing & Station Service Meter

- ☒ Properly installed and working totalizing & station service meter
- ☐ No totalizing meter
- ☐ No station service meter

*** Fuel Meter**

- ☒ Properly installed & working fuel meter
- ☐ No fuel meter

Environmental

Interior of Powerhouse

- ☐ Clean, well-kept
- ☒ Old generator part stored inside facility
- ☐ Waste oil stored inside facility
- ☐ Apparent oil spills

Under Facility

- ☒ Clean, well-kept
- ☐ Old generator part stored under facility
- ☐ Waste oil stored under facility
- ☐ Apparent oil spills

Surrounding of Powerhouse

- ☒ Clean, well-kept
- ☐ Old generator part stored on site
- ☐ Waste oil stored on site
- ☐ Apparent oil spills

*** Waste Oil Disposal**

- ☐ Waste oil blending system
- ☒ Waste oil incinerator
- ☐ Drum or tank storage for waste oils

*** Life, Health, & Safety**

- ☐ Code Compliant
- ☐ Low risk
- ☒ Medium risk
- ☐ High risk
- ☐ Potential for loss of life

Electrical Distribution Line Evaluation

Overhead Distribution System

* Pole type

- ☒ Fully treated poles
- ☐ Butt treated poles
- ☐ Native pole (trees)

* Pole installation

- ☐ Proper depth (can be determined by the manufacture's mark or button on pole)
- ☒ Within 12 inches of recommended depth
- ☐ Within 24 inches of recommended depth
- ☐ Greater than 24 inches of recommended depth

* Pole alignment

- ☐ Poles straight
- ☒ Poles leaning less than 10°
- ☐ Poles leaning greater than 10°

* Distribution voltage

- ☒ =>7200 volts
- ☐ 2400 volts
- ☐ 480/277 volts
- ☐ 208/120 volts

* Anchors

- ☒ Properly installed (<12 inches of the anchor rod exposed)
- ☐ 12 - 24 inches of the anchor rod exposed
- ☐ >24 inches of the anchor rod exposed

* Primary conductor

- ☒ Appears properly installed (sag, conductor size, etc)
- ☐ Improperly installed (conductor needs resagging, etc)

* Service conductor

- ☒ Appears properly installed (sag, conductor size, etc)
- ☐ Improperly installed (conductor needs resagging, etc)

*** Meter installation**

- ☐ Appears to be properly installed (height, grounding, etc)
- ☒ Improperly installed (height, no ground, etc)

*** Meter Condition Residential & Commercial**

- ☐ Good (appears in good condition)
- ☒ Fair (minor corrosion)
- ☐ Poor (major corrosion, needs replacing)

*** Over all condition of the system**

- ☐ Excellent (no repairs needed)
- ☒ Good (minor repairs, re-sag guys, re-sag service drops, etc.)
- ☐ Poor (major repairs needed, pole, guy, conductor, meter replacement, etc)

Underground Distribution System

*** Primary conductor**

- ☒ Appears to be properly installed
- ☐ Exposed conductor

*** Transformers**

- ☒ Appears to be properly installed
- ☐ Improperly installed (no pad, leaning, etc)

*** Service conductor**

- ☒ Appears to be properly installed
- ☐ Exposed conductor

Operator Proficiency

* Meter Reading

- ☐ Excellent
- ☒ Good
- ☐ Acceptable
- ☐ Unacceptable

* Daily Logs

- ☐ Excellent
- ☐ Good
- ☒ Acceptable
- ☐ Unacceptable

* Routine Maintenance

- ☐ Excellent
- ☐ Good
- ☒ Acceptable
- ☐ Unacceptable

* Scheduled Maintenance

- ☐ Excellent
- ☐ Good
- ☒ Acceptable
- ☐ Unacceptable

* Maintenance Planning

- ☐ Excellent
- ☐ Good
- ☒ Acceptable
- ☐ Unacceptable

Waste Heat Recovery

* Waste Heat Recovery Operational

☒ Yes

☐ No

List current users

School

* BTU/Hr Meter

☐ Yes

☒ No

* Additional Waste Heat Available

☐ No

☒ Yes

List Potential New Users

Public Bldg Port Alsworth improvement Corp

System Information

Supply / Return Delta T

35 deg F

Estimate of current annual heating fuel gallons displaced

14,600gal

Estimate of potential annual heating fuel gallons displaced

2,500gal

Existing Heat Sales Agreement(s)

None

General Questions

Use separate sheet(s) to answer these questions.

1. If records are available, indicate the number, duration, and causes of all forced outages during the last 12 months. If records are not available, provide whatever reasonable estimates available from utility personnel regarding outages number, duration, and causes. **Not Available**

ALASKA ENERGY AUTHORITY

VILLAGE POWER SYSTEM INVENTORY

DATE	Sept 8, 2012	TIME START	8:00a	TIME END	3:00p
COMMUNITY	Port Alsworth	UTILITY	Tanalian Electric Cooperative		
OWNERSHIP	Tanalian Elec Coop	CONTACT	Mark Lang		
OPERATOR	Andy Smith	PHONE	907-781-2224		

	G-1	G-2	G-3	G-4	G-5
ENGINE MAKE	John Deere	John Deere	John Deere		
ENGINE MODEL	6081AF001	6081AF001	6076AF-00		
ENGINE RPM	1800RPM	1800RPM	1800 RPM		
SERIAL NUMBER	RG6081A150577	RG6081A171816	RG6076A139717		
GOVERNOR TYPE	Woodward	Woodward	Mechanical		
MODEL ACTUATOR	8256	8256	Bosch Inline		
MODEL SPEED CONTROL	8290-040	8290-040	--		
DC VOLTAGE	12VDC	12VDC	12VDC		
UNIT CIRCUIT BREAKER	GE TJK636F000	GE TKG636F000	Westinghouse LC3600F		
TYPE/AMP/VOLT	600A / 600V	600A / 600V	600A / 600V		
CURRENT HOURS	24914	15278	1593		
GENERATOR MAKE	Stamford	Stamford	Stamford		
GENERATOR MODEL #	UCI274F13	UCI274G1L	SC434C		
GENERATOR SERIAL #	356329	A06B525790-1490 D	L2647/1		
GENERATOR CAPACITY (kW)	125kW	154kW	187kW		
GENERATOR VOLTAGE	120/208	120/208	120/208		
VOLTAGE REGULATOR, MAKE & MODEL	Newage MX341	Newage MX321-2	Newage 450-11700		
PARALLEL SWITCH GEAR (Y or N)	Yes	Yes	No		
kWh METER(Yes or No)	Yes				
POWERHOUSE kWh METER TYPE	GE				
CATALOG # or TYPE	700X66GL				
DEMAND ?	--				
CT RATIO	600:5				
STATION SERVICE METER (Yes or No)	Yes				
STATION SERVICE METER TYPE	Vectron				
CATALOG # or TYPE	FM125				
BATT. CHARGER/TYPE/MODEL	SENS FCA12-10-2411V				
FUEL DAY TANK TYPE	Simplex				
PUMP #	656508				
MOTOR #	Magnetek M-HG2G018				
FUEL DAY TANK METER	GM580				
FIRE PROTECTION	Fire Extinguishers				
TYPE/OPERATIONAL?					
ORIGINAL CONTRACTOR					