

Date: May 19, 2016

Project: Bulk Fuel Upgrade Project On behalf
of The City of Shishmaref, Alaska

Solicitation No.: 16004

Addendum No. Two

TO ALL PLANHOLDERS:

The enclosed addendum amends the bid documents for the above referenced Project.

Acknowledgment of this addendum is required on the Bid Submittal. Failure to do so may subject the bidder to disqualification.

Sincerely,

Rich Wooten, CDT, CPSM
Contract Compliance Specialist

ADDENDUM TO THE BID DOCUMENTS	Page Number 1	No. of Pages 1
Addendum No. TWO	Date Addendum Issued: May 19, 2016	
Issuing Office Rich Wooten, CDT, CPSM Alaska Energy Authority 813 W Northern Lights Blvd Anchorage, AK 99503 Phone: (907) 771-3019 Fax: (907) 771-3044	Previous Addenda Issued Addendum One, 5/16/2016	
Project: Bulk Fuel Upgrade Project On behalf of The City of Shishmaref, Alaska Solicitation No.: 16004	Date and Hour Quotes Due: May 23, 2016 at 2:00 p.m., prevailing Anchorage time.	

NOTICE TO BIDDERS:

Bidders must acknowledge receipt of this addendum prior to the hour and date set for proposal due date by one of the following methods:

- (a) By acknowledging receipt of this addendum on the proposal form submitted.
- (b) By email or telefacsimile which includes a reference to the project and addendum number.

The bid documents require acknowledgment individually of all addenda to the drawings and/or specifications. This is a mandatory requirement and any proposal received without acknowledgment of receipt of addenda may be classified as not being a responsive bid. If, by virtue of this addendum it is desired to modify a proposal already submitted, such modification may be made by email or telefacsimile provided such an email or telefacsimile makes reference to this addendum and is received prior to the opening hour and date specified above.

The Bid documents for the above project are amended as follows (All other terms and conditions remain unchanged):

GENERAL – QUESTIONS & ANSWERS

1) **Q:** On page C15, Detail 1, is the entire light pole w/ bracket owner provided?

A: All light poles are Contractor provided. A light pole mounting plate has been welded to the tank skid by the tank fabricator and is owner provided.

BID AND CONTRACT REQUIREMENTS

2) **Section 00800 Supplemental Conditions, SC 1 Project Schedule:** Change Bid Opening Date to May 23, 2016

3) **Section 01010 Summary of Work, 1.04.A.2.a:** Add the following to the end of the paragraph:

- (5) Large Ladder (US328-US332) 230Lbs. 13'-9" x 1'-10" x 3'-5"
- (2) Small Ladder (US333) 120 Lbs. 10'-10" x 1'-0" x 2'-2"
- (2) Walkway (US333) 200 Lbs. 2'-5" x 5'-5" x 2'-4"
- (5) 2'-0" x 3" Vent Pipe (US328-332) 15Lbs.
- (2) 6'-0" x 2" Vent Pipe (US333) 20Lbs.

The accessories will be packaged in two crates, both 4'-0" x 4'-0" x 15'-0"
Crate weights will be ±800 Lbs and ±1100 Lbs.

END OF ADDENDUM