



January 18, 2017

Invitation to Bid 17023 Kake & Kipnuk Fire Suppression
Addendum 1

The Bid due date remains the same.

Addendum 1 is issued to modify Appendix B, Scope and Drawings/Specifications

1. **Appendix B, Scope and Drawings/Specifications, page 10, add the following:**
 - A) **Substitutions** - All proposed substitutions must be submitted, and approved by the Authority before the bid opening.
 - B) **Salient Features** – In order for a substitution of the suppression system to be approved it must have at a minimum the following salient features:
 - 1) The system must use water mist as the sole extinguishing agent.
 - 2) The system must use high pressure (2,000 PSI nominal) nitrogen as the sole driving agent without the aid of any pumps.
 - 3) The system shall be a single pipe system utilizing stainless steel tubing not exceeding 1” outside diameter.
 - 4) The complete agent rack including all water and nitrogen storage for one zone of coverage shall not exceed the following dimensions: 4’-6” Long x 1’-4” Wide x 7’-6” High.
2. **Appendix B, Scope and Drawings/Specifications, page 12, Part 2 – Materials, 2.01:**
 - Change “Marioff Hi-Fog no substitutes” to “Marioff Hi-Fog or approved equal”
3. **Appendix B, Scope and Drawings/Specifications, page 12, Part 2 – Materials, 2.02:**
 - Change “Marioff Hi-Fog MAU 15 FS no substitutes” to “Marioff Hi-Fog or approved equal”
4. **Appendix B, Scope and Drawings/Specifications, page 14, Part 2 – Materials, 2.01:**
 - Change “Marioff Hi-Fog no substitutes” to “Marioff Hi-Fog or approved equal”

5. **Appendix B, Scope and Drawings/Specifications, page 14, Part 2 – Materials, 2.02:**

- Change “Marioff Hi-Fog MAU 15 FS no substitutes” to “Marioff Hi-Fog or approved equal”

As a reminder, all addendum must be acknowledged on the bid schedule.

Thank you,

Rich Wooten, CDT, CPSM
Contracting Officer
rwooten@aidea.org