

Date: February 13, 2017

Project: Kwigillingok Rural Power System
Upgrade – Distribution System

Solicitation No.: 17064

Addendum No. One

TO ALL PLANHOLDERS:

The enclosed addendum amends the bid documents for the above referenced Project.

Acknowledgment of this addendum is required on the Proposal Form. Failure to do so may subject the bidder to disqualification.

Sincerely,

Rich Wooten, CDT, CPSM
Contracting Officer

ADDENDUM TO CONTRACT DOCUMENTS	Page Number 1	No. of Pages Three (Attachment, 1 page)
Addendum No. ONE	Date Addendum Issued: February 13, 2017	
Issuing Office Rich Wooten, CDT, CPSM Alaska Energy Authority 813 W Northern Lights Blvd Anchorage, AK 99503 Phone: (907) 771-3019 Fax: (907) 771-3044	Previous Addenda Issued N/A	
Project: Kwigillingok Bulk Fuel and Rural Power System Upgrade – Distribution System Solicitation No.: 17064	Date and Hour Quotes Due: February 24, 2017 at 2:00 p.m., prevailing Anchorage time.	

NOTICE TO BIDDERS:

Bidders must acknowledge receipt of this addendum prior to the hour and date set for the bid due date by one of the following methods:

- (a) By acknowledging receipt of this addendum on the proposal form submitted.
- (b) By email or telefacsimile which includes a reference to the project and addendum number.

The bid documents require acknowledgment individually of all addenda to the drawings and/or specifications. This is a mandatory requirement and any bid received without acknowledgment of receipt of addenda may be classified as not being a responsive bid. If, by virtue of this addendum it is desired to modify a bid already submitted, such modification may be made by email or telefacsimile provided such an email or telefacsimile makes reference to this addendum and is received prior to the opening hour and date specified above.

The Bid documents for the above project are amended as follows (All other terms and conditions remain unchanged):

GENERAL – QUESTIONS & ANSWERS

- 1) **Q:** Concerning the descriptions provided in the project manual for Additive Alternates 1, 2, and 3 - Please clarify the difference between part A and part B of each additive alternate.

A: To clarify, the intent of Additive alternates 1A, 2A, and 3A is to provide all materials (piles, poles, hardware, conductors, and other equipment as specified) for the associated Additive Alternate Area, FOB Kwigillingok. The intent of Additive Alternates 1B, 2B, and 3B is to install the materials supplied in the associated Additive Alternate Area. This information is provided for clarification only, and does not modify the bid item descriptions provided in the contract documents.

- 2) **Q:** Is there a deadline for questions?

A: The deadline is 72 hours before the bid opening. Questions submitted after the deadline may be rejected by the Authority.

- 3) **Q:** Will you provide the pre-bid meeting sign-in sheet?

A: It is attached.

- 4) **Q:** Can you provide contact information for any Kwigillingok representatives?

A: Yes, they are as follows:

- The Kwigillingok Power Company Manger is William Igkurak, 907-588-8626 ext. 2.
- The Tribal Administrator is Andrew Beaver, 907-588-8114.
- The Tribal President is Arthur Lake, 907-588-8114.

BIDDING AND CONTRACT REQUIREMENTS

DIVISION 0 – BIDDING AND CONTRACT REQUIREMENTS

1. Section 00020 Invitation to Bid

Make the following change to the bid due date:

- **Change February 24, 2016 to February 24, 2017**

2. Section 00100-2 Information to Bidders

Add the following to the last paragraph of **Addenda Requirements**:

“The deadline for all questions is 72 hours before the bid opening. Questions submitted after the deadline may be rejected by the Authority”

DIVISION 1 – GENERAL REQUIREMENTS

Section 01100, paragraph 1.04. Change the following paragraphs as shown:

F. Additive Alternate 3A: Furnish Materials for Additive Alternate 3 Area

1. The lump sum bid for Additive Alternate 3A shall include but not be limited to full payment for all labor, material, freight and equipment required to furnish all materials required for construction of facilities in Additive Alternate 2 3 area FOB Kwigillingok, including all piling, poles, transformers, cross arms, guy anchors, guy lines, conductor, hardware and other components as shown on the plans and specifications. Provide secure storage for project materials in Kwigillingok.
2. Measurement for payment shall be lump sum complete in place.

E. Additive Alternate 3B: Install New System Components in Additive Alternate 3 Area

1. The lump sum bid for Additive Alternate 3B shall include but not be limited to full payment for all labor, material, freight and equipment required to install all system components in Additive Alternate 2 3 area to make a complete and functional system, including all piles, pole support angle brackets, helical anchors, poles, cross arms, guy anchors, conductor and associated components and hardware as shown on the plans and described in the project specifications.
2. Work shall also include energizing and testing the new system components in Additive Alternate 2 3 area and demolition of all existing system components taken out of service as a result work completed under this bid item in accordance with the project plans and specifications.
3. Work shall also include transportation of demolished items to the Kwigillingok Landfill or other location approved by the Utility and the Authority.
4. Measurement for payment shall be lump sum complete in place.

DIVISION 2 – SITE WORK

Section 02200, paragraph 1.02.E.3, change the date for the pile information to be submitted to the Contractor to August 15, 2017.

DRAWINGS

Sheet E1.3, General Notes, Add Note 12. The contractor shall be solely responsible for coordinating his work with existing facility operators, other contractors and/or subcontractors working in the community, local utility and government organizations, and state and federal authorities.

Sheet E1.3, General Notes, Add Note 13. The contractor shall be solely responsible for providing construction access for equipment and personnel as required to complete the pile driving, pole installation, pole hardware and conductor installation, and all other project tasks. Contractor shall coordinate with local entities and residents, erect temporary structures, and perform temporary removal/relocation and replacement of all structures, boardwalks, steam houses, etc. As necessary to complete the work. All existing structures affected by the work shall be returned to their original or better condition by the contractor immediately after the contractor's work in that area is completed. Contractor shall coordinate all necessary public safety activities including signage, barriers, traffic control plans, lighting, public notifications, and other items deemed necessary to protect the public during construction activities.

Sheet E1.3, General Notes, Add Note 14. The contractor shall balance the phases of the new distribution system. During construction load imbalance should be kept to a minimum and the unbalance shall not exceed 10%.

END OF ADDENDUM

February 8 at 2:00 p.m.
 Pre-proposal meeting for Kwigillingok RPSU
 Invitation to Bid 17064



Please print

Name	Firm	Telephone/Fax	Email
Rob Thompson	RTC	269-599-0154	rthompson@rtccorp.com
Mike Hamm	AML	907-351-8988	MHAMM@LYNDEN.COM
Rob Gambill	NPC	907-344-3436	rob@northernpowerline.com
MORTIMER MOORE	NPC	748-2801	MARCUS@NORTHERNPOWERLINE.COM
Tom Kelly	Potclom Sup.	907-982-1055	tkelly@potclom.com
Mike Morris	AML	907-227-6183	morris@lynden.com
Andrew Morton	AIDEA	907 771 3990	amorton@aidea.org
Lich Wooten	AEA / AIDEA	907-771-3019	lwooten@aidea.org
Alan Fettes	AEA	771-3063	afettes@aidea.org
ANDY KORZENIEWSKI	ALB	907-232-0731	AndyK@AKLinebuilders.com
CASEY VANDOR	ALB		CASEY@AKLinebuilders.com
Ben Miess	EPC	830-7304	Bmiess@EPConstructors.com
KARL HULSE	CRW	646-5621	KHULST@CRWeng.com
Tyler Keene	CRW	646-5856	tkeene@crweng.com