

Date: May 27, 2021

Project: Kassan Bulk Fuel Upgrade

Solicitation No.: 21125

Addendum No. Three

TO ALL PLANHOLDERS:

The enclosed addendum amends the bid documents for the above referenced Project.

Acknowledgment of this addendum is required on the Proposal Form. Failure to do so may subject the bidder to disqualification.

Sincerely,

DocuSigned by: Selwin Ray 0A1919DCB4834AC

Selwin C. Ray Contract Administrator

ADDENDUM TO CONTRACT DOCUMENTS	Page Number 1	No. of Pages Two
Addendum No. THREE	Date Addendum Issued: May 27, 2021	
Issuing Office Selwin C. Ray Alaska Energy Authority 813 W Northern Lights Blvd Anchorage, AK 99503 Phone: (907) 771-3035 Fax: (907) 771-3044	Previous Addenda Issued NONE	d
Project: Kassan Bulk Fuel Upgrade Solicitation No.: 21125	Date and Hour Bids Due: prevailing Anchorage time.	

NOTICE TO BIDDERS:

Bidders must acknowledge receipt of this addendum prior to the hour and date set for the bid due date by one of the following methods:

- (a) By acknowledging receipt of this addendum on the proposal form submitted.
- (b) By email or telefacsimile which includes a reference to the project and addendum number.

The bid documents require acknowledgment individually of all addenda to the drawings and/or specifications. This is a mandatory requirement and any bid received without acknowledgment of receipt of addenda may be classified as not being a responsive bid. If, by virtue of this addendum it is desired to modify a bid already submitted, such modification may be made by email or telefacsimile provided such an email or telefacsimile makes reference to this addendum and is received prior to the opening hour and date specified above.

The Bid documents for the above project are amended as follows (All other terms and conditions remain unchanged):

CONTRACT PROVISIONS AND SPECIFICATIONS

Item #1: Remove and replace Bid Schedule in its entirety

QUESTIONS AND ANSWERS

Question: Page G5 BULK TRANSFER EQUIPMENT: calls out the hose reel as owner provided. Tank Shop Drawing 3000gal page 1 of 2 Note in red says all apparatuses in red are to be provided by contractor or others. Can you clarify if it is owner provided or not?

Answer: The hose reel is owner-provided and already mounted on the skid of the 3,000-gallon tank.

Question: Page G4 PIPING: Calls out for all the piping to be owner provided and pre-finished and that the owner will provide touch up paint kits. How much field touch up is assumed and will there be enough touch up paint provided for touch ups and coating all the fittings if they are not pre-finished.

Answer: *Minimal paint touchup will be required due to the tanks arriving in good condition in Kasaan. There is sufficient paint on-site for the touchup required.*

BID SCHEDULE

Kasaan Bulk Fuel Upgrade Project No. 21125

Bidders Please Note: Before preparing this bid schedule, read carefully, "Information to Bidders", and the following:

The Bidder shall insert a fixed price in figures opposite each pay item that appears on the bid schedule to furnish all labor, material, equipment, supervision and provide all work for each item listed. No price is to be entered or tendered for any item not appearing in the bid schedule. In case of error in the extension of prices in the bid, the unit prices will govern; in a lot bid, the lot prices will govern.

Contract award shall be made on the basis of the Total Base Bid.

Bidder is required to bid on all Base bid items.

Conditioned or qualified bids will be considered non-responsive.

Item	Description	Quant.	Unit	Unit Price	Extended Total Amount
A1	Mobilization / Demobilization	1	LS	\$	\$
A2	Tank Farm Site Work	1	LS	\$	\$
A3	Point of Sale (POS) System	1	LS	\$	\$
A4	Pad Fill Material (Type 1) Complete in place	800	CY	\$	\$
A5	Cap Material (Type 2) Complete in place	150	CY	\$	\$
Total Base Bid					\$

Base Bid (Final Completion September 30, 2021

Note: See Section 01 11 13 Work Covered by Contract Documents for detailed descriptions of Bid Items.

YNI certify that I am entitled to:(1) 5% Alaska Bidder Preference[][]

2. Acknowledge all addenda

Addendum No	Date Issued	Addendum No	Date Issued	Addendum No	Date Issued

3. BIDDER'S NOTICE: By signature on this form, the Bidder certifies that:

a. The price(s) submitted are independent and without collusion.

b. The Bidder will comply with the laws of the State of Alaska;

c. The Bidder will comply with applicable portions of the Federal Civil Rights Act of 1964;

d. The Bidder will comply with the Equal Employment Opportunity Act and the regulations issued there under by the State and Federal Government; and

e. The Bidder has reviewed all terms and conditions in this Invitation to Bid.

If any Bidder fails to comply with any of these requirements, the Authority may reject its bid, terminate the contract, or consider the Vendor in default.

Company Submitting Bid	Telephone Number
Address	Fax Number
Address	
Authorized Signature	E-mail Address
Autionzed Signature	E-mail Address
Print Name	Alaska Business License number:
	EXPRES DATE:
	Alaska Contractor's Registration #
	EXPRES DATE:

End of Bid Schedule.