

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK	NO	SZ	BCK	NO	SZ																	
TYPE	SPN	TYPE	SPN	TYPE	SPN	TYPE	SPN	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS		
A D D								General														LOT	R2-20	Clearing will be required throughout the project. Clear as required to construct new facilities, and for the new circuits' continuing proper operation.	
E X I S T								School XFMR																	
A D D																						1	PLUG/PATCH	Plug hole in transformer fiberglass pad.	
E X I S T								Poles 1, 1-1, 1-2, 1-3																	
A D D																						4	M52-3	Number poles	
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>					<b>BY</b>	<b>LOCATION-</b>					<b>EEE, LLC</b>					<b>RPSU - AKIAK, ALASKA</b>							
0	4/20/12	ISSUED FOR CONSTRUCTION						<b>DATE-</b>																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						<b>ENGINEER-</b> Greg Errico																	
								<b>APPROVED-</b>					<b>WORK ORDER NO.:</b> ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR									LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY					NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ	BCK SPN																	
E X I S T						4	#2			127'	Pole 2	-/-	1	C7/C7d				1	G150 WYE - Δ				1	M2-11		
E X I S T						3	#2			-																
A D D						1	#2			-			1	N6								1	M52-3		Provide neutral deadend spool.	
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>					<b>BY</b>	<b>LOCATION-</b>					<b>EEE, LLC</b>					<b>RPSU - AKIAK, ALASKA</b>								
0	4/20/12	ISSUED FOR CONSTRUCTION						<b>DATE-</b>																		
1	2/18/15	ISSUED FOR CONSTR. - REV 1						<b>ENGINEER-</b> Greg Errico																		
								<b>APPROVED-</b>					<b>WORK ORDER NO.:</b> ITB# 15113													

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR							LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY			NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS			
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO															SZ	BCK SPN	
E X I S T							3 #2 ACSR	105'	Pole 3	-/-	1 C7R 1 C7d/A7dR 7 M5-5											1 M52-3	Upper C7R to remain.	
R E T I R E							3 - ACSR	-				2 E1-3	2 F1-4P											Retire electric guys and anchors.
R E T I R E							2 - ACSR	-																
A D D							1 #2 ACSR	105'			1 M5-20 2 M5-21 3 N6	1 M5-23P										1 M52-3	Convert lower framing to 3-phase double deadend framing. See jumpering detail.	
A D D							4 #2 ACSR	-																Install guy strain insulator (M5-23) in spanguy to pole 3A.
A D D							4 #2 ACSR	-																
A D D								Pole 3A	40/4			1 E1-3 1 E2-3	1 F1-4P									1 M52-3		
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>					<b>BY</b>	<b>LOCATION-</b>					<b>EEE, LLC</b>					<b>RPSU - AKIAK, ALASKA</b>						
0	4/20/12	ISSUED FOR CONSTRUCTION						<b>DATE-</b>																
1	2/18/15	ISSUED FOR CONSTR. - REV 1						<b>ENGINEER- Greg Errico</b>																
								<b>APPROVED-</b>					<b>WORK ORDER NO.: ITB# 15113</b>											

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR									LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY					NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS			
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ	BCK SPN																	
REPEAT																										
RETIRE							2	#2	170'	Pole B10A-1	-/-	1	A9-1d	1	E1-3	1	F1-4P			2	J6					
RETIRE				1	#2	-	2	#2	-																	
RETIRE				1	#2	-																				
A D D							4	#2	200'	Pole 3-1	45/4	1	C2R	1	E1-3	1	F1-4P			2	J6			1	M52-3	
A D D				1	1/0	-	2	#2	-															1	M26-5	
A D D				1	#2	-																				
NO	DATE	REVISION						BY	LOCATION-				EEE, LLC				RPSU - AKIAK, ALASKA									
0	4/20/12	ISSUED FOR CONSTRUCTION							DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1							ENGINEER- Greg Errico																	
									APPROVED-				WORK ORDER NO.: ITB# 15113													

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK	NO	SZ	BCK	NO	SZ																	
TYPE	SPN		TYPE	SPN		TYPE	SPN																		
A D D								Pole 3-1B	40/4		1	E1-3	1	F1-4P							1	M52-3			
REPEAT								Pole 3-1																	
E X I S T	1	-						Pole 3-1A	-/-																
RE T I R E				1	#2		95'										1	J6	1	K11					
					TRI																				
A D D				1	#2		95'				1	E1-3	1	F1-4P			1	J6	1	K10	1	M52-3			
					TRI															1	KSE				
A D D																									
	NO	DATE	REVISION				BY	LOCATION-					EEE, LLC					RPSU - AKIAK, ALASKA							
	0	4/20/12	ISSUED FOR CONSTRUCTION					DATE-																	
	1	2/18/15	ISSUED FOR CONSTR. - REV 1					ENGINEER- Greg Errico																	
								APPROVED-					WORK ORDER NO.: ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
E X I S T	1	-						SVCs off Pole 3-1A												1	K16				
RETIRE																				2	K16			Retire daisy-chained service fed from first.	
A D D	1	#2	80'																	1	K16			Provide separate service to second weatherhead.	
REPEAT								Pole 3-1																	
NO	DATE	REVISION					BY	LOCATION-						RPSU - AKIAK, ALASKA											
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-	EEE, LLC																
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER-	Greg Errico																
								APPROVED-						WORK ORDER NO.: ITB# 15113											



**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
REPEAT								Pole 3																	
EXIST								Pole B9	-/-																
RETIRE							3 - ACSR	79'													1	TOP	Retire all electrical appurtenances from pole; top pole only if required to provide clearances to new primary. Top minimum required.		
RETIRE							3 - ACSR																		
RELOCATE	1 - QUAD			1 - QUAD																			Re-locate quadraplex secondary from pole B8, to pole 4.		
ADD							4 #2 ACSR	191'	Pole 4	45/4				1	C1AR			1	G312-30	1	J6		1 M52-3 1 M2-11 1 M26-5	Set pole 8.5' deep.	
ADD							4 #2 ACSR																		
NO	DATE	REVISION					BY	LOCATION-					EEE, LLC					RPSU - AKIAK, ALASKA							
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-					WORK ORDER NO.: ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
E X I S T	1	-						Pole 4A (Old B8A-2)	-/-			1	F1-4P												
R E L O C A T E				1	-																			Re-locate quadruplex secondary to pole 4.	
R E T I R E											1	E1-3				1	J6	1	K11						
A D D											1	E1-3				1	J10	1	KSE	1	M52-3			Provide new guy to existing anchor.	
R E P E A T								Pole 4																	
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>					<b>BY</b>	<b>LOCATION-</b>					<b>EEE, LLC</b>					<b>RPSU - AKIAK, ALASKA</b>							
0	4/20/12	ISSUED FOR CONSTRUCTION						<b>DATE-</b>																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						<b>ENGINEER-</b> Greg Errico																	
								<b>APPROVED-</b>					<b>WORK ORDER NO.:</b> ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR							LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS		
	SERVICE			SECONDARY			PRIMARY			NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS					
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO															SZ	BCK SPN			
E X I S T							Pole B8	-/-																		
R E L O C A T E				1	-																			Re-locate quadruplex secondary to pole 4.		
R E T I R E				1	-				3	#2				3	XFMR	2	J6				1	TOP		Retire all electrical appurtenances from pole; top pole 2' above telecommunication facilities.		
R E T I R E				1	-				3	#2																
A D D									4	#2				1	C1AR	1	E1-3	1	F1-4P	1	G136-15	2	J6	1	M52-3 1	M2-11
A D D									4	#2																
A D D				1	1/0																					
A D D				1	1/0																					
NO	DATE	REVISION					BY	LOCATION-																		
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-						RPSU - AKIAK, ALASKA												
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER-	Greg Errico					EEE, LLC												
								APPROVED-						WORK ORDER NO.: ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
E X I S T								Pole 5A (Old B8A-1)	-/-													1	METERBASE		
R E T I R E				1	-						1	E1-3	1	F1-4P				1	J6					Retire guy and anchor.	
A D D				1	1/0						1	E1-3	1	F1-4P				1	J6	1	UM5/2	1	M52-3	The riser call out is for re-working of the meterbase's weatherhead riser on the pole; add 10' stick of IMC conduit; replace service entrance cables with new copper cables; ground riser with pipe grounding clamp to new pole ground.	
A D D	3	#2 CU																						Provide new guy and anchor.	
R E P E A T								Pole 5																	
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>					<b>BY</b>	<b>LOCATION-</b>					<b>EEE, LLC</b>					<b>RPSU - AKIAK, ALASKA</b>							
0	4/20/12	ISSUED FOR CONSTRUCTION						<b>DATE-</b>																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						<b>ENGINEER-</b> Greg Errico																	
								<b>APPROVED-</b>					<b>WORK ORDER NO.:</b> ITB# 15113												





**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
E X I S T								Pole B7	-/-																
RETIRE							3 #2 ACSR	266'			2 C7d	1 E1-3	1 F1-4P	1 XFMR	1 J6							1 TOP	Retire all electrical appurtenances from pole; top pole 2' above telecommunication facilities.		
RETIRE							3 #2 ACSR	-																	
RETIRE				1 - TRI																					
A D D							4 #2 ACSR	266'	Pole 6	45/4	1 C1AR	1 E1-3	1 F1-4P	1 G136-15	2 J6							1 M52-3 1 M2-11 1 M26-5			
A D D							4 #2 ACSR	-																	
A D D				1 1/0 TRI																					
A D D				1 1/0 TRI																					
NO	DATE	REVISION					BY	LOCATION-					EEE, LLC					RPSU - AKIAK, ALASKA							
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-					WORK ORDER NO.: ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR									LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY					NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ	BCK SPN																	
E X I S T	1	-								Pole 6A (Old B7A-1)																
RETIRE				1	-						40/4								3	J6	1	K11				
RETIRE				1	-																					
RETIRE				1	-																					
A D D				1	1/0		120'				40/4								1	J5	1	K11	1	M52-3	Relocate pole in-line with poles 6 and 6B.	
A D D				1	1/0																					
A D D				1	#2																					
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>						<b>BY</b>	<b>LOCATION-</b>																	
0	4/20/12	ISSUED FOR CONSTRUCTION							DATE-					RPSU - AKIAK, ALASKA												
1	2/18/15	ISSUED FOR CONSTR. - REV 1							ENGINEER- Greg Errico					EEE, LLC												
									APPROVED-					WORK ORDER NO.: ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
E X I S T	1	-						Pole 6AA (Old B7A-2)	-/-																
R E T I R E				1	-		79'										1	J6	2	K11					
R E L O C A T E	1	-																						Re-locate service to Lot 1A, to pole 6B.	
A D D				1	#2		84'										1	J6	1	K11	1	M52-3			
R E P E A T								Pole 6A (Old B7A-1)																	
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>					<b>BY</b>	<b>LOCATION-</b>					<b>EEE, LLC</b>					<b>RPSU - AKIAK, ALASKA</b>							
0	4/20/12	ISSUED FOR CONSTRUCTION						<b>DATE-</b>																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						<b>ENGINEER-</b> Greg Errico																	
								<b>APPROVED-</b>					<b>WORK ORDER NO.:</b> ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
E X I S T	1	-						Pole 6B (Old B7A- 3)	40/5																
R E T I R E				1	-													1	J6	1	K11				
R E L O C A T E	1	-																						Re-locate service to Lot 1A, to this pole.	
A D D				1	1/0		120'				1	E1-3	1	F1-4P			1	J10	2	KSE	1	M52-3			
R E P E A T								Pole 6 (Old B7)																	
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>					<b>BY</b>	<b>LOCATION-</b>					<b>EEE, LLC</b>					<b>RPSU - AKIAK, ALASKA</b>							
0	4/20/12	ISSUED FOR CONSTRUCTION						<b>DATE-</b>																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						<b>ENGINEER-</b> Greg Errico																	
								<b>APPROVED-</b>					<b>WORK ORDER NO.:</b> ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS	
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS		
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																		BCK SPN
E X I S T									Pole 6C (Old C16)	-/-																
RETIRE							3	#2	53'			1	C2d													Retire all primary facilities from pole.
							ACSR					1	C7d													
RETIRE							3	#2	-																	
							ACSR																			
RETIRE							3	#2	-																	
							ACSR																			
A D D				1	1/0	53'					1	E1-3	1	F1-4P			2	J6			1	M52-3				
				TRI																						
A D D				1	#2	-																				
				TRI																						
RELOCATE	1	-																							Re-locate service to Lot 2, to this pole.	
A D D				1	#2	86'			Pole 6D	40/5 (or larger)							1	J6	1	K11	1	M52-3				
				TRI																						
NO	DATE	REVISION					BY	LOCATION-					EEE, LLC					RPSU - AKIAK, ALASKA								
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																		
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																		
								APPROVED-					WORK ORDER NO.: ITB# 15113													



**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK	NO	SZ	BCK	NO	SZ																	
TYPE	SPN	TYPE	SPN	TYPE	SPN	TYPE	SPN	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS				
E X I S T									-/-														Tangent pole to remain.		
RETIRE	2	4/0	-			3	#2	185'	Poles C18 & C19	-/-	1	C1d	1	E1-3	1	F1-4P	3	75 kVA XFMR		2	K11	2	M2-11	Retire old-step-up transformer bank, platform, framing, service drops, and all apputerances on both poles. Salvage deadend pole for re-use.	
	QUAD					ACSR																			
RETIRE						3	#2	11'																	
						ACSR																			
RETIRE	2	4/0	35'						Old Power Plant											2	K16				
	QUAD																								
REPEAT									Pole 6 (Old B7)																
NO	DATE	REVISION					BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-									RPSU - AKIAK, ALASKA								
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER-	Greg Errico								EEE, LLC								
								APPROVED-									WORK ORDER NO.: ITB# 15113								

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
RETIRE								Pole B7-GP	40/4		1	E1-3	1	F1-4P											Salvage pole for re-use.
REPEAT								Pole 6 (Old B7)																	
RELOCATE	1	-																							Re-locate service to Lot 5A, to this pole.
	TRI																								
ADD						4	#2	225'	Pole 7	45/4	1	C1AR	1	E1-3	1	F1-4P	1	G136-10	2	J6	1	K11	1	M52-3	
						ACSR																	1	M2-11	
ADD			1	1/0		4	#2																		
			TRI			ACSR																			
ADD			1	1/0																					
			TRI																						
NO	DATE	REVISION					BY	LOCATION-					EEE, LLC					RPSU - AKIAK, ALASKA							
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-					WORK ORDER NO.: ITB# 15113												



**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR							LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY			NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS			
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO															SZ	BCK SPN	
E X I S T							Pole C14	-/-																
RETIRE						3 #2 ACSR	169'			1	C1d			1	XFMR	2	J6							Retire all electrical appurtenances from pole.
RETIRE				1	-	3 #2 ACSR	-																	
RETIRE				1	-																			
E X I S T							Pole C13	-/-																
RETIRE						3 #2 ACSR	159'			1	C1d	1	E1-3	1	F1-4P									Retire all electrical appurtenances from pole. Do not top pole, unless required.
RETIRE						3 #2 ACSR	-																	
NO	DATE	REVISION					BY	LOCATION-	EEE, LLC						RPSU - AKIAK, ALASKA									
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																
								APPROVED-	WORK ORDER NO.: ITB# 15113															

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
E X I S T								Pole C12	-/-																
RETIRE						3	#2	141'		1	C1d			1	XFMR	1	J6	1	k11	1	M26-5			Retire all electrical appurtenances from pole.	
RETIRE			1	-		3	#2	-																	
				TRI		ACSR																			
RETIRE			1	-																					
				TRI																					
RELOCATE	1	-																						Re-locate service to home north on Lot 1, to pole 9-1B.	
NO	DATE	REVISION					BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-						RPSU - AKIAK, ALASKA											
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER-	Greg Errico					EEE, LLC											
								APPROVED-						WORK ORDER NO.: ITB# 15113											

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
REPEAT								Pole 7																	
EXIST	1	-																							
	TRI																								
RETIRE				1	-	40'		C13B-2	-/-								1	J6	2	K11				Retire pole.	
				TRI																					
RELOCATE	1	-																						Re-locate service to Lot 1B, to pole 9.	
	TRI																								
ADD				1	1/0	127'	4 #2	Pole 8	45/4	1	C1AR	1	E1-3	1	F1-4P		1	J10	1	KSE	1	M52-3			
				TRI			ACSR															1	M26-5		
ADD							4 #2																		
							ACSR																		
NO	DATE	REVISION					BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-										RPSU - AKIAK, ALASKA							
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico					EEE, LLC												
								APPROVED-										WORK ORDER NO.: ITB# 15113							

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
RELOCATE	1	-																						Re-locate service to Lot 1B, to this pole.	
A D D						4	#2	145'	Pole 9	45/4	1	C1AR			1	G136-10			1	K11	1	M52-3	See jumpering detail.		
						1					1	C10										1	M2-11		
																						1	M26-5		
A D D						4	#2	-																	
A D D						4	#2	-																	
A D D						4	#2	-																	
A D D						4	#2	50'	Pole 9-1E	45/4	1	C7-2A	2	E1-3	2	F1-4P						1	M52-3	Install one guy to each anchor; Install second guy 7' below first.	
NO	DATE	REVISION					BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-						RPSU - AKIAK, ALASKA											
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER-	Greg Errico					EEE, LLC											
								APPROVED-						WORK ORDER NO.: ITB# 15113											

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
REPEAT								Pole 9																	
A D D						4	#2	185'	Pole 9-1	45/4	1	C1AR			1	G136-10	1	J6			1	M52-3	Set pole 8.5' deep. Install secondary to pole 9-1A at reduced tension.		
						ACSR																			
A D D						4	#2	-																	
						ACSR																			
A D D				1	1/0																				
				TRI																					
A D D				1	1/0			57'	Pole 9-1A	40/4			1	E1-3	1	F1-4P			2	J6		1	M52-3		
				TRI																		1	GUARD POST		
A D D				1	1/0																				
				TRI																					
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>					<b>BY</b>	<b>LOCATION-</b>					<b>EEE, LLC</b>					<b>RPSU - AKIAK, ALASKA</b>							
0	4/20/12	ISSUED FOR CONSTRUCTION						<b>DATE-</b>																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						<b>ENGINEER- Greg Errico</b>																	
								<b>APPROVED-</b>					<b>WORK ORDER NO.: ITB# 15113</b>												



**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK	NO	SZ	BCK	NO	SZ																	
E X I S T	1	-							Pole 9-1C	30/5															
RETIRE				1	-			117'										1	J6	1	K11				
A D D	1	#2		1	1/0			117'										1	J6	1	K10	1	M52-3		
E X I S T	1	-							SVCs off Pole 9-1C											1	K16				
RETIRE																				2	K16			Retire daisy-chained service fed from first.	
A D D	1	#2						99'												1	K16			Provide separate service to second weatherhead.	
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>					<b>BY</b>	<b>LOCATION-</b>					<b>EEE, LLC</b>					<b>RPSU - AKIAK, ALASKA</b>							
0	4/20/12	ISSUED FOR CONSTRUCTION						<b>DATE-</b>																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						<b>ENGINEER-</b> Greg Errico																	
								<b>APPROVED-</b>					<b>WORK ORDER NO.:</b> ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
REPEAT								Pole C12																	
E X I S T								Pole C11	-/-		1	E1-3	1	F1-4P											
RETIRE						3	#2			1	C1d														
								157'																	
RETIRE						3	#2																		
								-																	
REPEAT								Pole 9-1																	
NO	DATE	REVISION					BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-					EEE, LLC					RPSU - AKIAK, ALASKA							
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-										WORK ORDER NO.: ITB# 15113							

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
A D D						4	#2	162'	Pole 9-2	45/4	1	C1AR	1	E1-3	1	F1-4P							1	M52-3	
						1	A7-1																		
A D D						4	#2	-																	
						ACSR																			
A D D						2	#2	-																	
						ACSR																			
A D D						2	#2	255'	Pole 9-2-1	45/4	1	A7-1	2	E1-3	2	F1-4P	1	G136-15	1	J6			1	M52-3	
						ACSR																	1	M2-11	
																							1	M26-5	
																							2	RSC2LS	
A D D				1	1/0																				
				TRI																					
A D D				2	4/0																				
				URD																					
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>					<b>BY</b>	<b>LOCATION-</b>					<b>EEE, LLC</b>					<b>RPSU - AKIAK, ALASKA</b>							
0	4/20/12	ISSUED FOR CONSTRUCTION						<b>DATE-</b>																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						<b>ENGINEER-</b> Greg Errico																	
								<b>APPROVED-</b>					<b>WORK ORDER NO.:</b> ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
RELOCATE	1	-																						Re-locate service to building south of pole, to this pole.	
ADD				1	1/0		57'		Pole 9-2-1A	40/5 (or larger)		1	E1-3	1	F1-4P			1	J6	1	KSE	1	M52-3		
				1	#2																				
RELOCATE	1	-																						Re-locate service to building east of pole, to this pole.	
ADD				1	#2		57'		Pole 9-2-1B	40/5 (or larger)								1	J10	1	KSE	1	M52-3		
REPEAT									Pole 9-2-1																
NO	DATE	REVISION					BY	LOCATION-	EEE, LLC								RPSU - AKIAK, ALASKA								
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico									WORK ORDER NO.: ITB# 15113								
								APPROVED-																	

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK	NO	SZ	BCK	NO	SZ																	
A D D	2	#2		1	4/0				Ped S1								1	UK5			75'	UR2-5			
																					40'	UR2C-5			
																					120'	HDPE2			
E X I S T									Bldg. East of Ped S1																
A D D	1	#2																					25'	UR2-5	
																							30'	HDPE2	
																							1	UG-SVC-RISER- TRANS	
E X I S T									Bldg. West of Ped S1																
A D D	1	#2																					20'	UR2-5	
																							25'	HDPE2	
																							1	UG-SVC-RISER- TRANS	
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>					<b>BY</b>	<b>LOCATION-</b>					<b>EEE, LLC</b>					<b>RPSU - AKIAK, ALASKA</b>							
0	4/20/12	ISSUED FOR CONSTRUCTION						<b>DATE-</b>																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						<b>ENGINEER-</b> Greg Errico																	
								<b>APPROVED-</b>					<b>WORK ORDER NO.:</b> ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR									LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY					NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS			
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ	BCK SPN																	
REPEAT																										
										Pole 9-2-1																
A D D	2	#2		1	4/0					Ped S2									1	UK5			40'	UR2-5		
																							40'	UR2C-5		
																							170'	HDPE2		
E X I S T										Bldg. East of Ped S2																
A D D	1	#2																					20'	UR2-5		
																							25'	HDPE2		
																							1	UG-SVC-RISER- TRANS		
E X I S T										Bldg. West of Ped S2																
A D D	1	#2																					25'	UR2-5		
																							30'	HDPE2		
																							1	UG-SVC-RISER- TRANS		
	NO	DATE	REVISION				BY	LOCATION-					EEE, LLC					RPSU - AKIAK, ALASKA								
	0	4/20/12	ISSUED FOR CONSTRUCTION					DATE-																		
	1	2/18/15	ISSUED FOR CONSTR. - REV 1					ENGINEER- Greg Errico																		
								APPROVED-					WORK ORDER NO.: ITB# 15113													

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
REPEAT																									
EXIST									Pole C10	-/-															
RETIRE				1	-						1	C1d					2	J6			1	TOP			Retire all electrical appurtenances from pole; top pole 2' above telecommunication facilities.
RETIRE				1	-																				
ADD							4	#2	125'	Pole 9-3	45/4	1	C1AR			1	G136-10	2	J6			1	M52-3		
ADD							4	#2	-																
ADD				1	#2																				
ADD				1	#2																				
NO	DATE	REVISION					BY	LOCATION-					EEE, LLC					RPSU - AKIAK, ALASKA							
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-					WORK ORDER NO.: ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
E X I S T	1	-	-						Pole 9-3A	-/-															
	TRI																								
R E T I R E				1	-													1	J6	1	K11				
				TRI				107'																	
A D D				1	#2							1	E1-3	1	F1-4P			1	J6	1	K11	1	M52-3		
				TRI				107'																	
A D D																									
R E P E A T									Pole 9-3																
R E L O C A T E	1	-	-																						
	TRI																								
A D D				1	#2				Pole 9-3B	40/5 (or larger)								1	J6	1	K11	1	M52-3		
				TRI				69'																	
NO	DATE	REVISION					BY	LOCATION-	EEE, LLC						RPSU - AKIAK, ALASKA										
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-							WORK ORDER NO.: ITB# 15113										

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR							LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY			NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS			
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO															SZ	BCK SPN	
REPEAT							Pole 9-3 (Old C10)																	
EXIST	1	-					Pole C9	-/-																
RETIRE				1	-	161'			1	C1d				1	XFMR	3	J6	1	K11	1	TOP		Retire all electrical appurtenances from pole; top pole 2' above telecommunication facilities.	
RETIRE									3	#2														
						333'				ACSR														
RETIRE				2	-				3	#2														
										ACSR														
ADD									4	#2				1	G136-10	1	J10	1	KSE	1	M52-3	1	M2-11	Set pole 8.5' deep.
						161'	Pole 9-4	45/4		ACSR														
ADD				1	#2																			
										ACSR														
NO	DATE	REVISION					BY	LOCATION-																
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-						RPSU - AKIAK, ALASKA										
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER-	Greg Errico					EEE, LLC										
								APPROVED-						WORK ORDER NO.: ITB# 15113										

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
E X I S T	1	-	-						Pole 9-4A (Old C9B-1)	-/-															
RETIRE				1	-													1	J6	1	K11			Retire secondary and its attachment. Retire service attachment.	
				TRI				68'																	
A D D				1	#2													1	J6	1	K11	1	M52-3	Attach new secondary and service at 9" from pole top.	
				TRI				68'																	
REPEAT									Pole 9-4																
RELOCATE	1	-	-																					Re-locate service to Lot 6, to pole 9-3B.	
				TRI																					
E X I S T									Pole C9A-1																
RETIRE	1	-	-	1	-													1	J6	2	K11			Retire all electrical appurtenances from pole.	
				TRI				83'																	
NO	DATE	REVISION						BY	LOCATION-	EEE, LLC						RPSU - AKIAK, ALASKA									
0	4/20/12	ISSUED FOR CONSTRUCTION							DATE-																
1	2/18/15	ISSUED FOR CONSTR. - REV 1							ENGINEER- Greg Errico																
									APPROVED-	WORK ORDER NO.: ITB# 15113															

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
REPEAT								Pole 9-4																	
EXIST								Pole C8	-/-																
RETIRE						3 #2	177'			2 C1d 1 C7d	2 E1-3	2 F1-4P												Retire all electrical appurtenances from pole.	
RETIRE						2 #2	-																		
RETIRE						3 #2	-																		
RETIRE						3 #2	-																		
NO	DATE	REVISION					BY	LOCATION-						RPSU - AKIAK, ALASKA											
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-	EEE, LLC																
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER-	Greg Errico																
								APPROVED-						WORK ORDER NO.: ITB# 15113											

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR						LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS	
	SERVICE			SECONDARY					PRIMARY			NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO		UNITS
	NO	SZ	BCK SPN	NO	SZ	BCK SPN			NO	SZ	BCK SPN													
REPEAT							Pole 9-4																	
A D D						4 #2 ACSR	229'	Pole 9-5	45/4	1 C7-1R 1 A5-2	3 E1-3	2 F1-4P	1 G136-10	1 J6					1 M52-3 1 M2-11 1 M26-5			Provide two primary guys and anchors to back-up three phase primary. Install 1st guy at 9" below crossarms; install second guy 7" lower.		
A D D						2 #2 ACSR	-																	
A D D				1 1/0 TRI																				
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>				<b>BY</b>	<b>LOCATION-</b>				<b>EEE, LLC</b>				<b>RPSU - AKIAK, ALASKA</b>									
0	4/20/12	ISSUED FOR CONSTRUCTION					<b>DATE-</b>																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1					<b>ENGINEER-</b> Greg Errico																	
							<b>APPROVED-</b>				<b>WORK ORDER NO.:</b> ITB# 15113													



**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR						LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS	
	SERVICE			SECONDARY					PRIMARY			NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO		UNITS
	NO	SZ	BCK SPN	NO	SZ	BCK SPN			NO	SZ	BCK SPN													
E X I S T																								
RETIRE				1	-	153'	Pole A8A-3	-/-									2	J6						
RETIRE				1	-	-																		
E X I S T							Pole A8A-4	-/-																
RELOCATE	2	-	-																				Relocate services to new pole 9-5C.	
RETIRE				1	-	81'											1	J6	2	K11				
REPEAT							Pole 9-5A																	
NO	DATE	REVISION				BY	LOCATION-	EEE, LLC					RPSU - AKIAK, ALASKA											
0	4/20/12	ISSUED FOR CONSTRUCTION					DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1					ENGINEER- Greg Errico																	
							APPROVED-						WORK ORDER NO.: ITB# 15113											

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
A D D				1	1/0				Pole 9-5B	40/4		1	E1-3	1	F1-4P			3	J6			1	M52-3		
A D D				1	#2																				
A D D				1	1/0																				
E X I S T	1	-							Pole 9-5BA																
R E T I R E				1	-													1	J6	1	K11				
A D D				1	#2													1	J6	1	K11	1	M52-3		
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>					<b>BY</b>	<b>LOCATION-</b>					<b>EEE, LLC</b>					<b>RPSU - AKIAK, ALASKA</b>							
0	4/20/12	ISSUED FOR CONSTRUCTION						<b>DATE-</b>																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						<b>ENGINEER-</b> Greg Errico																	
								<b>APPROVED-</b>					<b>WORK ORDER NO.:</b> ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
REPEAT								Pole 9-5B																	
RELOCATE	2	-																						Relocate services from A8A-4 to this pole.	
ADD				1	1/0		161'	Pole 9-5C	40/4		1	E1-3	1	F1-4P		1	J6	2	K11	1	M52-3				
REPEAT								Pole 9-5 (Old C8A-1)																	
	NO	DATE	REVISION				BY	LOCATION-				EEE, LLC		RPSU - AKIAK, ALASKA											
	0	4/20/12	ISSUED FOR CONSTRUCTION					DATE-																	
	1	2/18/15	ISSUED FOR CONSTR. - REV 1					ENGINEER- Greg Errico																	
								APPROVED-				WORK ORDER NO.: ITB# 15113													

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR							LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY			NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS			
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO															SZ	BCK SPN	
E X I S T							Pole C8B-1	-/-																
RETIRE										1	C1d													
RETIRE																								
RELOCATE	2	-																						Re-locate service to Lot 3, and adjacent building on Lot 5, to this pole.
A D D	1	#2								1	A2	2	E1-3	2	F1-4P			1	J10	3	KSE	1	M52-3	
A D D				1	1/0																			
NO	DATE	REVISION				BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION					DATE-					EEE, LLC					RPSU - AKIAK, ALASKA							
1	2/18/15	ISSUED FOR CONSTR. - REV 1					ENGINEER- Greg Errico																	
							APPROVED-										WORK ORDER NO.: ITB# 15113							

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
E X I S T								Bldg. on Lot 5																	
R E T I R E	1	-	76'																	1	K16				
A D D	1	#2	79'																	1	K16				
R E P E A T								Pole 9-6																	
NO	DATE	REVISION					BY	LOCATION-	EEE, LLC					RPSU - AKIAK, ALASKA											
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico						WORK ORDER NO.: ITB# 15113											
								APPROVED-																	

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
E X I S T	1	-						Pole C8B-2	-/-																
R E L O C A T E	1	-																						Re-locate service to building south of Lot 3, to pole 9-6.	
R E T I R E						3	#2		132'							1	J6	2	K11	1	M26-5				
						ACSR																			
R E T I R E						3	#2		-																
						ACSR																			
A D D				1	1/0	123'	2	#2	123'	Pole 9-7	45/4	1	A1A			1	G105-15	2	J6	1	K11	1	M52-3		
				TRI			ACSR										2	UM5/2				1	M2-11		
																						1	M26-5		
																						2	RSC2LS		
A D D				1	1/0		2	#2																	
				TRI			ACSR																		
A D D				2	4/0																				
				URD																					
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>					<b>BY</b>	<b>LOCATION-</b>					<b>DATE-</b>					<b>ENGINEER-</b>					<b>APPROVED-</b>		
0	4/20/12	ISSUED FOR CONSTRUCTION						RPSU - AKIAK, ALASKA					RPSU - AKIAK, ALASKA					EEE, LLC							
1	2/18/15	ISSUED FOR CONSTR. - REV 1						Greg Errico					WORK ORDER NO.:					ITB# 15113							



**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR									LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY					NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK	NO	SZ	BCK	NO	SZ	BCK																	
TYPE	SPN	TYPE	SPN	TYPE	SPN	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS			
REPEAT										Pole 9-7																
A D D	2	#2		1	4/0					Ped S2									1	UK5			55'	UR2-5		
	URD			URD		250'																40'	UR2C-5			
																						205'	HDPE2			
E X I S T										Bldg. East of Ped S2																
A D D	1	#2																					65'	UR2-5		
	URD		85'																				70'	HDPE2		
																							1	UG-SVC-RISER- TRANS		
E X I S T										Bldg. South of Ped S2																
A D D	1	#2																					20'	UR2-5		
	URD		40'																				25'	HDPE2		
																							1	UG-SVC-RISER- TRANS		
NO	DATE	REVISION						BY	LOCATION-	EEE, LLC								RPSU - AKIAK, ALASKA								
0	4/20/12	ISSUED FOR CONSTRUCTION							DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1							ENGINEER- Greg Errico									WORK ORDER NO.: ITB# 15113								
									APPROVED-																	

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
REPEAT								Pole 9-7 (Old C8B-2)																	
EXIST	2	-						Pole C8B-3																	
RETIRE				1	-		129'		-/-	1 C1d 1 C7d	3 E1-3	2 F1-4P	1 XFMR	3 J6	3 K11									Retire transformer, platform, framing, service attachments, secondary attachments, and both poles.	
RETIRE				2	-		-		-/-																
ADD				1	1/0		117'	Pole 9-8	45/4	1 A1A			1 G105-15	2 J6	1 K11 1 K10 1 KSE	1 M52-3 1 M2-11 2 RSC2LS							Establish secondary normal open to pole 9-7.		
ADD				1	1/0		-																		
ADD	1	#2																						Only provide service to old school generator building, if metering exists.	
	NO	DATE	REVISION				BY	LOCATION-				EEE, LLC				RPSU - AKIAK, ALASKA									
	0	4/20/12	ISSUED FOR CONSTRUCTION					DATE-																	
	1	2/18/15	ISSUED FOR CONSTR. - REV 1					ENGINEER- Greg Errico																	
								APPROVED-				WORK ORDER NO.: ITB# 15113													

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
E X I S T								Old School Generator Bldg.																	
RETIRE	1	-	63'																	1	K16				
A D D	1	#2	67'																	1	K16			Only provide service to old school generator building, if metering exists.	
REPEAT								Pole 9-8 (Old C8B-3)																	
RETIRE				1	-	59'		Pole C8B-4	-/-										1	J6					
NO	DATE	REVISION					BY	LOCATION-	EEE, LLC						RPSU - AKIAK, ALASKA										
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico							WORK ORDER NO.: ITB# 15113										
								APPROVED-																	

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR						LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE		SECONDARY		PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK	NO	SZ	BCK																	
REPEAT							Pole 9-8																
EXIST	1	-					Pole C8B-5																
RETIRE				1	-	145'		-/-								2	J6	1	K11				
RETIRE				1	-	-																	
ADD				1	1/0	145'	2 #2 ACSR	145'	Pole 9-9	45/4	1	A5			1	G105-10	2	J6	1	K11	1	M52-3	Begin installation of primary span guy to pole 9-9A
					TRI																1	M2-11	
ADD				1	1/0	-																	
					TRI																		
NO	DATE	REVISION				BY	LOCATION-																
0	4/20/12	ISSUED FOR CONSTRUCTION					DATE-																
1	2/18/15	ISSUED FOR CONSTR. - REV 1					ENGINEER- Greg Errico				EEE, LLC				RPSU - AKIAK, ALASKA								
							APPROVED-								WORK ORDER NO.: ITB# 15113								



**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
REPEAT								Pole 9																	
A D D						4	#2	137'	Pole 10	45/4	1	C1AR										1	M52-3		
A D D						4	#2	-																	
NO	DATE	REVISION					BY	LOCATION-						RPSU - AKIAK, ALASKA											
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-	EEE, LLC																
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER-	Greg Errico																
								APPROVED-						WORK ORDER NO.: ITB# 15113											



**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
REPEAT								Pole 11																	
RELOCATE	1	-																						Re-locate services on pole A15A-1 to this pole.	
ADD				1	#2		42'	Pole 11B	40/5 (or larger)							1	J6	1	K11	1	M52-3				
REPEAT								Pole 11																	
	NO	DATE	REVISION				BY	LOCATION-																	
	0	4/20/12	ISSUED FOR CONSTRUCTION					DATE-					EEE, LLC												
	1	2/18/15	ISSUED FOR CONSTR. - REV 1					ENGINEER- Greg Errico					RPSU - AKIAK, ALASKA												
								APPROVED-					WORK ORDER NO.: ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
RELOCATE	1	-																						Re-locate service to Lot 1A to this pole.	
	TRI																								
ADD				1	1/0				Pole 11C	40/4		1	E1-3	1	F1-4P			2	J6	1	K11	1	M52-3		
				TRI		145'																			
ADD				1	1/0																				
				TRI		-																			
RELOCATE	1	-																						Re-locate service to Lot 1A to pole 11C.	
	TRI																								
EXIST	2	-																							
	TRI									-/-															
RETIRE				1	-													2	J6	3	K11				
				TRI		-																			
ADD				1	1/0				Pole 11D			1	E1-3	1	F1-4P			1	J6	1	K10	1	M52-3		
				TRI		83'														1	KSE				
NO	DATE	REVISION					BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-							RPSU - AKIAK, ALASKA										
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER-	Greg Errico						EEE, LLC										
								APPROVED-							WORK ORDER NO.: ITB# 15113										

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR									LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY					NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ	BCK SPN																	
REPEAT										Pole 11																
ADD							4	#2	200'	Pole 12	45/4	1	C1AR	1	E1-3	1	F1-4P	1	G136-10	3	J6			1	M52-3	
							ACSR																	1	M26-5	
							4	#2	-																	
				1	1/0																					
				TRI																						
				1	1/0																					
				TRI																						
RELOCATE	1	-																								Re-locate service on pole A13 to this pole.
				1	1/0					Pole 12A	40/4			1	E1-3	1	F1-4P			1	J10	1	KSE	1	M52-3	Install anchor 3' out-of-line south of from secondary.
				TRI		127'																				
NO	DATE	REVISION						BY	LOCATION-				EEE, LLC				RPSU - AKIAK, ALASKA									
0	4/20/12	ISSUED FOR CONSTRUCTION							DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1							ENGINEER- Greg Errico																	
									APPROVED-				WORK ORDER NO.: ITB# 15113													

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
REPEAT								Pole 12																	
A D D	1	#2	-	1	1/0	161'		Pole 12B	40/4		1	E1-3	1	F1-4P		2	J6	1	K11	1	M52-3		Provide new service to Lot 3.		
A D D				1	1/0																				
E X I S T								Home on Lot 3																	
RE T I R E	1	-																		1	K16				
A D D	1	#2	79'																	1	K16				
NO	DATE	REVISION					BY	LOCATION-					EEE, LLC					RPSU - AKIAK, ALASKA							
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-					WORK ORDER NO.: ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
REPEAT								Pole 12B																	
RELOCATE	1	-																						Re-locate service to Lot 1B from pole A12B-2U-2 to this pole.	
ADD	1	#2		1	1/0		165'	Pole 12C	40/4		1	E1-3	1	F1-4P		1	J6		1	K10	1	M52-3	Provide new service to Lot 2B.		
EXIST								Home on Lot 2B																	
RETIRE	1	-																		1	K16				
ADD	1	#2					69'													1	K16				
NO	DATE	REVISION					BY	LOCATION-	EEE, LLC						RPSU - AKIAK, ALASKA										
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-	WORK ORDER NO.: ITB# 15113																



**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
E X I S T	2	-						Pole 13A	-/-				1	F1-4P											
R E L O C A T E	1	-																						Re-locate service northeast to Lot 4, to pole 15-N4A.	
R E T I R E				1	-						1	E1-3				1	J6	3	K11						
A D D				1	#2	80'					1	E1-3				1	J6	1	K10	1	M52-3				
R E P E A T								Pole 13																	
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>					<b>BY</b>	<b>LOCATION-</b>					<b>EEE, LLC</b>					<b>RPSU - AKIAK, ALASKA</b>							
0	4/20/12	ISSUED FOR CONSTRUCTION						<b>DATE-</b>																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						<b>ENGINEER-</b> Greg Errico																	
								<b>APPROVED-</b>					<b>WORK ORDER NO.:</b> ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
E X I S T								Pole 13B (Old A12B-2U)	-/-																
R E L O C A T E	1	-																						Re-locate service west to home from pole A12-B3, to this pole.	
R E T I R E										1	A9-1d														
										1	A8d														
R E T I R E																									
R E T I R E																									
R E T I R E																									
R E T I R E																									
A D D				1	#2													1	J10	1	KSE	1	M52-3		
							59'																		

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
E X I S T								Pole B1	-/-																
RETIRE						2	#2	108'			2	A7d	2	E1-3											
							ACSR																		
RETIRE						2	#2	-																	
							ACSR																		
E X I S T								Pole B2	-/-																
RETIRE																						1	TOP	Top pole 5' above telecommunications.	
REPEAT								Pole B1																	
NO	DATE	REVISION					BY	LOCATION-					EEE, LLC					RPSU - AKIAK, ALASKA					WORK ORDER NO.: ITB# 15113		
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-																	



**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK	NO	SZ	BCK	NO	SZ																	
TYPE	SPN	TYPE	SPN	TYPE	SPN	TYPE	SPN	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS		
RELOCATE	2	-																						Re-locate 1st service to pole 13B. Re-locate 2nd service to pole 13-2A.	
EXIST								Pole A12B-3	-/-																
RETIRE				1	-		64'			1	A7d	1	E1-3	1	F1-4P	1	XFMR	1	J6	2	K11	1	M26-5		
RETIRE						2	#2																	Backspan to pole 13B.	
REPEAT								Pole B3																	
NO	DATE	REVISION					BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-					EEE, LLC					RPSU - AKIAK, ALASKA							
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-										WORK ORDER NO.: ITB# 15113							



**STAKING SHEET**

EXIST REIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
E X I S T	1	-						Pole 13-1A (Old B3B)	-/-																
RETIRE				1	-		74'											3	J6	1	K11			Span to pole B3	
RETIRE				1	-		178'																	Span to pole 13A.	
RETIRE				1	-		-																		
A D D				1	#2		75'											1	J6	1	K11	1	M52-3		
E X I S T								Pole B3BC	-/-																
RETIRE	1	-		1	-		138'											1	J6	1	K11				
	NO	DATE	REVISION				BY	LOCATION-					EEE, LLC					RPSU - AKIAK, ALASKA							
	0	4/20/12	ISSUED FOR CONSTRUCTION					DATE-																	
	1	2/18/15	ISSUED FOR CONSTR. - REV 1					ENGINEER- Greg Errico																	
								APPROVED-					WORK ORDER NO.: ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR							LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY			NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS			
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO															SZ	BCK SPN	
REPEAT																								
							Pole 13-1																	
EXIST	1	-					Pole B4	-/-																
RETIRE	1	-							1	A7d	2	E1-3	2	F1-4P	1	XFMR	1	J6	2	K11	1	TOP	Top pole 2' above telecommunications. Retire service to load center.	
	TRI																							
RETIRE				1	-																			
				TRI																				
ADD	1	#2							1	A9	1	E2-3			1	G136-10	1	J6	1	K10	1	M52-3		
	TRI						Pole 13-2	45/4									1	J10	2	KSE	1	M2-11		
																					1	M26-5		
ADD																								
ADD				1	#2																			
				TRI																				
ADD				1	#2																			
				TRI																				
NO	DATE	REVISION					BY	LOCATION-																
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-						RPSU - AKIAK, ALASKA										
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER-	Greg Errico					EEE, LLC										
								APPROVED-						WORK ORDER NO.: ITB# 15113										

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK	NO	SZ	BCK	NO	SZ																	
TYPE	SPN	TYPE	SPN	TYPE	SPN	TYPE	SPN	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS		
E X I S T								L.C.																	
RETIRE	1	-																		1	K16				
	TRI		47'																						
A D D	1	#2																		2	K16	1	INTERMEDIATE MAST	Install an intermediate mast on load center post. Install K16 for on intermediate mast at 17' to provide service clearance over road.	
	TRI		51'																						
REPEAT								Pole 13-2																	
RELOCATE	1	-																						Re-locate southeast service, to this pole.	
	TRI																								
A D D				1	#2			Pole 13-2A	40/4		1	E2-3	1	F1-4P		1	J6	1	K11	1	M52-3				
				TRI			32'				1	E1-3													
NO	DATE	REVISION					BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-						RPSU - AKIAK, ALASKA											
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER-	Greg Errico					EEE, LLC											
								APPROVED-						WORK ORDER NO.: ITB# 15113											

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
REPEAT																									
A D D	1	#2	-	1	#2	97'			Pole 13-2B	40/5 (or larger)									1	J6	1	K11	1	M52-3	
E X I S T									Home on Lot 1																
RE T I R E	1	-	67'	1	-																2	K16			Begin retirement of triplex span to pole B3BA (sourced from this home's weatherhead).
A D D	1	#2	59'																		1	K16			
RE P E A T									Pole 13-2																
NO	DATE	REVISION					BY	LOCATION-	EEE, LLC						RPSU - AKIAK, ALASKA										
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-	WORK ORDER NO.: ITB# 15113																

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
E X I S T	2	-						Pole B5	-/-																
RETIRE				1	-		201'											2	J6	2	K11	1	TOP	Top pole 3' 6" below new secondary height	
RETIRE				1	-																				
A D D							201'	Pole 13-3	45/4	1	A2	1	E2-3				1	J10	2	KSE	1	M52-3			
A D D				1	1/0																				
A D D								Pole 13-3A	40/4			1	E2-3	1	F1-4P							1	M52-3		
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>					<b>BY</b>	<b>LOCATION-</b>					<b>EEE, LLC</b>					<b>RPSU - AKIAK, ALASKA</b>							
0	4/20/12	ISSUED FOR CONSTRUCTION						<b>DATE-</b>																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						<b>ENGINEER-</b> Greg Errico																	
								<b>APPROVED-</b>					<b>WORK ORDER NO.:</b> ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR							LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY			NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS			
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO															SZ	BCK SPN	
REPEAT							Pole 13-3																	
EXIST	2	-					Pole B6	-/-																
RETIRE				1	-	173'										3	J6	2	K11	1	TOP		Top pole 3' 6" below new secondary height	
RETIRE				1	-	-																		
RETIRE				1	-	-																		
ADD				1	1/0	173'	Pole 13-4	45/4	1	A1A					1	J5	1	K10	1	M52-3				
ADD				1	1/0	-																		
	NO	DATE	REVISION			BY	LOCATION-		EEE, LLC				RPSU - AKIAK, ALASKA											
	0	4/20/12	ISSUED FOR CONSTRUCTION				DATE-																	
	1	2/18/15	ISSUED FOR CONSTR. - REV 1				ENGINEER- Greg Errico																	
							APPROVED-						WORK ORDER NO.: ITB# 15113											

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
E X I S T	1	-						Pole B7																	
RETIRE				1	-		160'		-/-								2	J6	1	K11					
RETIRE				1	-																				
A D D				1	1/0		160'	2 #2 ACSR	160'	Pole 13-5	45/4	1	A5	1	E1-3	1	F1-4P	1	G105-15	1	J5	1	K10	1	M52-3 M2-11
A D D				1	1/0																				
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>					<b>BY</b>	<b>LOCATION-</b>					<b>EEE, LLC</b>					<b>RPSU - AKIAK, ALASKA</b>							
0	4/20/12	ISSUED FOR CONSTRUCTION						<b>DATE-</b>																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						<b>ENGINEER-</b> Greg Errico																	
								<b>APPROVED-</b>					<b>WORK ORDER NO.:</b> ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR									LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY					NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ	BCK SPN																	
E X I S T	2	-								Pole 13-6	-/-															
RETIRE				1	-				155'										2	J6	2	K11				
RETIRE				1	-				-																	
A D D				1	1/0				155'										1	J5	1	K10	1	M52-3		
A D D				1	1/0				-																	
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>					<b>BY</b>	<b>LOCATION-</b>					<b>EEE, LLC</b>					<b>RPSU - AKIAK, ALASKA</b>								
0	4/20/12	ISSUED FOR CONSTRUCTION						<b>DATE-</b>																		
1	2/18/15	ISSUED FOR CONSTR. - REV 1						<b>ENGINEER-</b> Greg Errico																		
								<b>APPROVED-</b>					<b>WORK ORDER NO.:</b> ITB# 15113													



**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR							LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS	
	SERVICE			SECONDARY			PRIMARY			NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS				
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO															SZ	BCK SPN		
E X I S T																									
RETIRE							Pole A12B-1U	-/-																	
									1	A9-1d															
RETIRE									2	#2															
									171'	ACSR															
RETIRE																									
RETIRE																									
E X I S T							Pole A12	-/-																	
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																									
RETIRE																</									

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
REPEAT								Pole 13																	
RELOCATE	1	-																						Re-locate service to Lot 5, to this pole.	
A D D						4	#2	188'	Pole 14	45/4	1	C1AR			1	G136-10			1	K11	1	M52-3	1	M2-11	
A D D						4	#2	-																	
A D D				1	#2																				
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>					<b>BY</b>	<b>LOCATION-</b>					<b>EEE, LLC</b>					<b>RPSU - AKIAK, ALASKA</b>							
0	4/20/12	ISSUED FOR CONSTRUCTION						<b>DATE-</b>																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						<b>ENGINEER-</b> Greg Errico																	
								<b>APPROVED-</b>					<b>WORK ORDER NO.:</b> ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
E X I S T	1	-						Pole 14A	-/-																
R E L O C A T E	1	-																						Re-locate service to Lot 5, to pole 14.	
R E T I R E				1	-															2	K11			Backspan to pole A12.	
A D D				1	#2														1	J6	1	K11	1	M52-3	
E X I S T	1	-						Home on Lot 2													1	K16			
R E T I R E	1	-																			1	K16		Begin retirement of triplex span to home on Lot 1 to the north (sourced from this home's weatherhead).	
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>					<b>BY</b>	<b>LOCATION-</b>																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-					EEE, LLC												
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico															RPSU - AKIAK, ALASKA		
								APPROVED-					WORK ORDER NO.: ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
REPEAT								Pole A12																	
RELOCATE				1	-																			Re-locate secondary to pole 15-1.	
RETIRE						3	#2	139'	Pole A12A	-/-	1	C1dX			3	XFMR	1	J6							
RETIRE						2	#2																		
RELOCATE	1	-		1	-																			Re-locate service to pole 15-1A.	
RETIRE									Pole A12A-1	-/-							1	J6	1	K11					
NO	DATE	REVISION					BY	LOCATION-	EEE, LLC					RPSU - AKIAK, ALASKA											
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-						WORK ORDER NO.: ITB# 15113											

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
REPEAT								Pole A12																	
EXIST	1	-						Pole 15-1B (Old A13)	-/-																
RELOCATE	1	-																						Relocate service to Lot 4 to pole 12A.	
RETIRE				1	-					1	A9-1d					1	J6	2	K11						
				TRI			174'																		
ADD				1	#2						1	E1-3	1	F1-4P		1	J10	1	KSE	1	M52-3				
				TRI																					
REPEAT								Pole 14																	
NO	DATE	REVISION					BY	LOCATION-	EEE, LLC					RPSU - AKIAK, ALASKA											
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-						WORK ORDER NO.: ITB# 15113											

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR									LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY					NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ	BCK SPN																	
A D D							4	#2		145'	Pole 15	45/4	1	C10			1	G136-10	1	J6			1	M52-3	See jumpering detail.	
							4	#2																		
A D D							4	#2																		
A D D							4	#2																		
A D D				1	#2																					
RELOCATE	1	-																							Relocate services to Lot 6, from pole A11 to this pole.	
A D D				1	#2						Pole 15A	40/4							1	J6	1	K11	1	M52-3		
	NO	DATE	REVISION						BY	LOCATION-				EEE, LLC				RPSU - AKIAK, ALASKA								
	0	4/20/12	ISSUED FOR CONSTRUCTION							DATE-																
	1	2/18/15	ISSUED FOR CONSTR. - REV 1							ENGINEER- Greg Errico																
										APPROVED-				WORK ORDER NO.: ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
REPEAT								Pole 15																	
RELOCATE				1	-																			Re-located secondary from pole A12A.	
ADD						4	#2	267'	Pole 15-1	45/4	1	C7-1R	2	E1-3	2	F1-4P	1	G312X- 10-15-10	2	J6			1	M52-3	Frame A7X on backside of C7-1R.
						1	A7X																		
						2	#2																		
							ACSR																		
RELOCATE																								Re-located service from pole A12A-1.	
ADD									Pole 15-1A	40/5 (or larger)									1	J6	1	K11	1	M52-3	
NO	DATE	REVISION						BY	LOCATION-																
0	4/20/12	ISSUED FOR CONSTRUCTION							DATE-									RPSU - AKIAK, ALASKA							
1	2/18/15	ISSUED FOR CONSTR. - REV 1							ENGINEER-	Greg Errico								EEE, LLC							
									APPROVED-									WORK ORDER NO.: ITB# 15113							

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
REPEAT								Pole 15-1																	
RELOCATE	1	-																						Relocate service to Lot 3 from pole A15, to this pole.	
A D D						2	#2	132'	Pole 15-2	45/4	1	A2	2	E1-3	1	F1-4P	1	G105-10	1	J6	1	K11	1	M52-3 M2-11	
A D D						2	#2	-																	
A D D				1	1/0																				
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>					<b>BY</b>	<b>LOCATION-</b>					<b>EEE, LLC</b>					<b>RPSU - AKIAK, ALASKA</b>							
0	4/20/12	ISSUED FOR CONSTRUCTION						<b>DATE-</b>																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						<b>ENGINEER-</b> Greg Errico																	
								<b>APPROVED-</b>					<b>WORK ORDER NO.:</b> ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS	
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS		
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																		BCK SPN
E X I S T									Pole 15-2A (Old A14)	-/-																
RETIRE							2	#2	191'			1	A9-1D													
							ACSR																			
RETIRE							2	#2	-																	
													1	E1-3	1	F1-4P			3	J6			1	M52-3		
A D D				1	1/0	84'																				
				TRI																						
A D D				1	1/0	-																				
				TRI																						
A D D				1	#2	-																				
				TRI																						
RELOCATE	1	-																							Relocate service to Lot 2 from pole A15-2, to this pole.	
				TRI																						
A D D				1	1/0	91'			Pole 15-2B	40/4			1	E1-3	1	F1-4P			1	J10	1	KSE	1	M52-3		
				TRI																						
NO	DATE	REVISION						BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION							DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1							ENGINEER- Greg Errico				EEE, LLC				RPSU - AKIAK, ALASKA									
									APPROVED-								WORK ORDER NO.: ITB# 15113									

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
REPEAT								Pole 15-2A (Old A14)																	
RELOCATE	1	-																						Relocate service to Lot 2 from pole A15, to this pole.	
ADD				1	#2		88'	Pole 15-2C	40/5 (or larger)							1	J10	1	KSE	1	M52-3		Set pole 8.5' deep.		
REPEAT								Pole 15-2																	
NO	DATE	REVISION					BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-					EEE, LLC												
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico					RPSU - AKIAK, ALASKA												
								APPROVED-					WORK ORDER NO.: ITB# 15113												



**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK	NO	SZ	BCK	NO	SZ																	
E X I S T									Pole A15	-/-															
RELOCATE	3	-		1	-																			Relocate services to poles 15-2, 15-2C, and 15-3. Relocate secondary to poles 15-3.	
RETIRE											1	A7d	1	E1-3	1	F1-4P	1	XFMR	3	J6	3	K11			
RETIRE				2	-																				
RETIRE				2	-																				
RELOCATE	3	-																						Relocate services to Lot 6, to pole 11A. Relocate service to Lot 5, to pole 11B.	
RETIRE				1	-				Pole A15A-1	-/-									1	J6	3	K11			

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
REPEAT								Pole A15																	
RELOCATE	1	-																						Relocate services to Lot 2, to pole 15-2B.	
RETIRE				1	-	85'		Pole A15A-2	-/-							1	J6	1	K11						
REPEAT								Pole 15																	
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>					<b>BY</b>	<b>LOCATION-</b>					<b>EEE, LLC</b>					<b>RPSU - AKIAK, ALASKA</b>							
0	4/20/12	ISSUED FOR CONSTRUCTION						<b>DATE-</b>																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						<b>ENGINEER-</b> Greg Errico																	
								<b>APPROVED-</b>					<b>WORK ORDER NO.:</b> ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
A D D						4	#2		162'	Pole 15-N1	45/4	1	C7-1R	1	E1-3	1	F1-4P					1	M52-3	Frame A7X on backside of C7-1R.	
						1	A7X																		
						2	M5-5																		
A D D						2	#2		-																
							ACSR																		
A D D						2	#2		-																
							ACSR																		
RETIRE				1	-					Pole 15-N2 (OLD)	-/-														
							TRI																		
RETIRE				1	-																				
							TRI																		
A D D						2	#2		169'	Pole 15-N2	45/4	1	A2	1	E1-3	1	F1-4P					1	M52-3		
							ACSR																		
A D D						2	#2		-																
							ACSR																		
A D D						2	#2		-																
							ACSR																		
NO	DATE	REVISION					BY	LOCATION-					EEE, LLC					RPSU - AKIAK, ALASKA							
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-					WORK ORDER NO.: ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
RELOCATE	1	-																						Relocate service to pole 15-N2-1A.	
	TRI																								
RETIRE				1	-				Pole 15-N2-1 (OLD)	-/-								1	J6						
				TRI		155'																			
A D D							2	#2	Pole 15-N2-1 (OLD)	45/4	1	A5	1	E1-3	1	F1-4P	1	G105-10	1	J6			1	M52-3	
							ACSR	193'															1	M2-11	
																								Set pole 8.5' deep.	
RELOCATE	1	-																							
	TRI																								
A D D				1	#2				Pole 15-N2 -1A	40/5 (or larger)									1	J6	1	K11	1	M52-3	
				TRI		193'																			
REPEAT									Pole 15-N2																
NO	DATE	REVISION					BY	LOCATION-	EEE, LLC					RPSU - AKIAK, ALASKA											
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-						WORK ORDER NO.: ITB# 15113											

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK	NO	SZ	BCK	NO	SZ																	
RELOCATE	1	-		1	-																			Relocate service to north, to this pole. Relocate secondary from pole 15-N3A, to this pole.	
	TRI			TRI																					
ADD							2 #2	127'	Pole 15-N3	45/4	1	A1A			1	G105-10	1	J6	1	K11	1	M52-3			
							ACSR																		
ADD							2 #2	-																	
							ACSR																		
EXIST	1	-		1	-				Pole 15-N3A	-/-															
	TRI			TRI																					
RETIRE				1	-			159'									1	J6	1	K11					
				TRI																					
ADD																	1	J6	1	K11	1	M52-3			
NO	DATE	REVISION					BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-										RPSU - AKIAK, ALASKA							
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico					EEE, LLC												
								APPROVED-										WORK ORDER NO.: ITB# 15113							



**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR									LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY					NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ	BCK SPN																	
RELOCATE	1	-																							Relocate service from pole 13A, to this pole.	
ADD				1	1/0					Pole 15-N4A	40/4			1	E1-3	1	F1-4P			1	J6	1	K11	1	M52-3	
REPEAT										Pole 15-N4																
NO	DATE	REVISION					BY	LOCATION-																		
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-					EEE, LLC					RPSU - AKIAK, ALASKA								
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																		
								APPROVED-										WORK ORDER NO.: ITB# 15113								



**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
E X I S T	1	-						Pole 15-N5A	-/-				1	F1-4P									1	M2-11	
R E T I R E																									
A D D				1	1/0								1	E1-3					1	J6			1	M52-3	
R E P E A T								Pole 15-N5																	
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>					<b>BY</b>	<b>LOCATION-</b>					<b>EEE, LLC</b>					<b>RPSU - AKIAK, ALASKA</b>							
0	4/20/12	ISSUED FOR CONSTRUCTION						<b>DATE-</b>																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						<b>ENGINEER-</b> Greg Errico																	
								<b>APPROVED-</b>					<b>WORK ORDER NO.:</b> ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR							LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY			NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS			
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO															SZ	BCK SPN	
E X I S T							Pole 15-N5B	-/-																
RETIRE						2 #2 ACSR	69'			1 A9-1d														
RETIRE						2 #2 ACSR	-																	
A D D				1 1/0 TRI			69'				1 E1-3	1 F1-4P				1 J6					1 M52-3			
E X I S T							Pole B3A-1	-/-																
RETIRE						2 #2 ACSR	134'			1 A9d	1 E1-3	1 F1-4P												
RETIRE						2 #2 ACSR	143'																	Primary to pole B3.
NO	DATE	REVISION					BY	LOCATION-	EEE, LLC					RPSU - AKIAK, ALASKA										
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																
								APPROVED-						WORK ORDER NO.: ITB# 15113										

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
REPEAT								Pole 15-N5																	
RETIRE	1	-																							
	TRI																								
RELOCATE	1	-																						Relocate service north to home, to this pole.	
	TRI																								
A D D						2	#2	210'	Pole 15-N6	45/4	1	A1A	1	E2-3			1	J6	1	K11	1	M52-3			
						ACSR																			
A D D			1	1/0		2	#2																		
			TRI			ACSR																			
NO	DATE	REVISION					BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-						RPSU - AKIAK, ALASKA											
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER-	Greg Errico					EEE, LLC											
								APPROVED-						WORK ORDER NO.: ITB# 15113											

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR						LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS					
	SERVICE			SECONDARY					PRIMARY			NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO		UNITS				
	NO	SZ	BCK SPN	NO	SZ	BCK SPN			NO	SZ	BCK SPN																	
E X I S T																												
RETIRE	1	-	35'																									
RETIRE	1	-	161'																				Complete retirement of triplex from weatherhead at home on Lot 1.					
REPEAT																												
ADD				1	1/0	163'	2	#2	163'	Pole 15-N7	45/4	1	A2	2	E1-3	2	F1-4P	1	G105-10	2	J6			1	M52-3			
ADD																								1	M26-5			
ADD							2	#2																				
ADD				1	1/0																							
NO	DATE	REVISION				BY	LOCATION-				EEE, LLC				RPSU - AKIAK, ALASKA				WORK ORDER NO.: ITB# 15113									
0	4/20/12	ISSUED FOR CONSTRUCTION					DATE-																					
1	2/18/15	ISSUED FOR CONSTR. - REV 1					ENGINEER- Greg Errico																					
							APPROVED-																					

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
E X I S T	2	-						Pole 15-N7A	-/-																
RETIRE				1	-												1	J6	2	K11					
				TRI																					
A D D				1	1/0		101'				1	E2-3	1	F1-4P			1	J10	2	KSE	1	M52-3			
				TRI							1	E1-3													
E X I S T								Pole B6-1	-/-																
RETIRE				1	-		217'										3	J6							
				TRI																					
RETIRE				1	-		137'																	Secondary to pole B6.	
				TRI																					
RETIRE				1	-																				
				TRI																					
NO	DATE	REVISION					BY	LOCATION-	EEE, LLC					RPSU - AKIAK, ALASKA											
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-						WORK ORDER NO.: ITB# 15113											

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
RELOCATE	1	-																						Relocate service to home on Lot 14, to pole 15-N8.	
	TRI																								
EXIST								Pole B6-2	-/-																
RETIRE	1	-		1	-	111'											1	J6	2	K11					
	TRI			TRI																					
REPEAT								Pole 15-N7																	
NO	DATE	REVISION					BY	LOCATION-							RPSU - AKIAK, ALASKA										
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-	EEE, LLC																
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER-	Greg Errico																
								APPROVED-							WORK ORDER NO.: ITB# 15113										

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK	NO	SZ	BCK	NO	SZ																	
RELOCATE	1	-																						Relocate service to home on Lot 14, to this pole.	
	TRI																								
ADD	1	#2				2	#2	239'	Pole 15-N8	45/4	1	A5	1	E1-3	1	F1-4P	1	G105-10		1	K10	1	M52-3		
	TRI					ACSR															1	KSE	1	M2-11	
EXIST									Home on Lot 15																
RETIRE	1	-																			1	K16			
	TRI		39'																						
ADD	1	#2																			1	K16			
	TRI		63'																						
NO	DATE	REVISION					BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico					EEE, LLC					RPSU - AKIAK, ALASKA							
								APPROVED-										WORK ORDER NO.: ITB# 15113							

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
REPEAT								Pole A12																	
EXIST								Pole A11	-/-																
RELOCATE	1	-																						Relocate service to home on Lot 6, to pole 15A.	
RETIRE						3	#2			1	C1d					1	J6	1	K11						
								159'																	
RETIRE			1	-		3	#2																		
NO	DATE	REVISION					BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico					EEE, LLC												
								APPROVED-																	
															RPSU - AKIAK, ALASKA										
															WORK ORDER NO.: ITB# 15113										

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR							LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS	
	SERVICE			SECONDARY			PRIMARY			NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS				
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO															SZ	BCK SPN		
E X I S T							Pole A10	-/-																	
RETIRE				1	-	145'			3	#2					1	XFMR	2	J6							
				TRI					ACSR																
RETIRE				1	-				3	#2															
				TRI					ACSR																
REPEAT							Pole 15																		
A D D							Pole 16	45/4	4	#2	213'			1	C7-1R	1	E1-3	1	F1-4P				1	M52-3	Frame A7X on backside of C7-1R.
									ACSR																
A D D									2	#2															
									ACSR																
NO	DATE	REVISION					BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-						RPSU - AKIAK, ALASKA											
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER-	Greg Errico					EEE, LLC											
								APPROVED-						WORK ORDER NO.: ITB# 15113											

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK	NO	SZ	BCK	NO	SZ																	
RELOCATE	1	-																						Relocate service to home on Lot 2, to this pole.	
ADD										1	A1A					1	G105-10	2	J6	1	K11	1	M52-3		
								Pole 17	45/4																
ADD																									
ADD				1	1/0																				
ADD				1	1/0																				
NO	DATE	REVISION					BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-										RPSU - AKIAK, ALASKA							
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico					EEE, LLC												
								APPROVED-										WORK ORDER NO.: ITB# 15113							

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK	NO	SZ	BCK	NO	SZ																	
E X I S T								Pole 17D (Old A9)	-/-																
RETIRE				1	-			145'		3	#2								1	J6	2	K11	1	M26-5	
				TRI						ACSR											1	K16			
RETIRE										3	#2														
										ACSR															
RELOCATE	1	-																						Relocate service to home on Lot 2, to the north, to pole 17.	
	TRI																								
RELOCATE	1	-																						Relocate service to first church building, to pole 17E.	
	TRI																								
RELOCATE	1	-																						Relocate service to second church building (service daisy chained off first service), to pole 17E.	
	TRI																								
A D D				1	1/0			47'					1	E1-3	1	F1-4P			2	J6			1	M52-3	
				TRI																			1	M26-5	
A D D				1	#2																				
				TRI																					
NO	DATE	REVISION					BY	LOCATION-					EEE, LLC					RPSU - AKIAK, ALASKA							
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-					WORK ORDER NO.: ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK	NO	SZ	BCK	NO	SZ																	
TYPE	SPN		TYPE	SPN		TYPE	SPN																		
RELOCATE	1	-																					Relocate service to first church building, to this pole.		
	TRI																								
RELOCATE	1	-																					Relocate service to second church building (service daisy chained off first service), to this pole.		
	TRI																								
A D D			1	#2	86'				Pole 17E	40/4		1	E1-3	1	F1-4P			1	J6	1	K10	1	M52-3		
			TRI																						
REPEAT									Pole 17																
RELOCATE	1	-																					Relocate service to Lot 1, to this pole.		
	TRI																								
A D D			1	1/0	154'				Pole 17A	40/4		2	E1-3	2	F1-4P			2	J6	1	K11	1	M52-3		
			TRI																						
A D D			1	1/0																					
			TRI																						
NO	DATE	REVISION					BY	LOCATION-					EEE, LLC					RPSU - AKIAK, ALASKA							
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-					WORK ORDER NO.: ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
RELOCATE	1	-						Pole 17B	40/4															Relocate service to home to the north, to this pole.	
ADD				1	1/0						1	E1-3	1	F1-4P				2	J6	1	K11	1	M52-3		
				TRI			146'																		
ADD				1	#2																				
				TRI			-																		
EXIST	1	-						Pole 17C	-/-												1	K11			
				TRI																					
RETIRE				1	-						1	E1-3	1	F1-4P				1	J6	2	K11				
				TRI			-																		
RELOCATE	2	-																						Relocate service to Lot 1, Block 1, to pole 17A. Relocate service to home to the north, to pole 17B.	
				TRI																					
ADD				1	#2														1	J6	1	K11	1	M52-3	
				TRI			60'																		
NO	DATE	REVISION					BY	LOCATION-	EEE, LLC					RPSU - AKIAK, ALASKA											
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-						WORK ORDER NO.: ITB# 15113											

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR						LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS	
	SERVICE			SECONDARY					PRIMARY			NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO		UNITS
	NO	SZ	BCK SPN	NO	SZ	BCK SPN			NO	SZ	BCK SPN													
REPEAT							Pole 17																	
A D D						2 #2 ACSR	146'	Pole 18	45/4	1	A1A			1	G105-10	1	J6			1	M52-3	1	M2-11	Set pole 8.5' deep.
A D D						2 #2 ACSR	-																	
A D D				1	1/0																			
NO	DATE	REVISION				BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION					DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1					ENGINEER- Greg Errico				EEE, LLC				RPSU - AKIAK, ALASKA									
							APPROVED-								WORK ORDER NO.: ITB# 15113									

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
E X I S T	2	-						Pole 18A (Old A8)	-/-																
RETIRE				1	-	161'	3 #2	161'		1	C1d			1	XFMR	4	J6	2	K11						
RETIRE				1	-		3 #2																		
RETIRE				1	-	147'																	Span to pole 17C.		
RETIRE				1	-																				
A D D				1	1/0	49'										1	J6	1	K10	1	M52-3				
REPEAT								Pole 18																	
NO	DATE	REVISION					BY	LOCATION-					EEE, LLC					RPSU - AKIAK, ALASKA							
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-					WORK ORDER NO.: ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
RELOCATE	1	-																						Relocate service to Lot 4, from pole A6A-1, to this pole.	
A D D						2	#2	231'	Pole 19	45/4	1	A2	1	E1-3	1	F1-4P	1	G105-10	1	J6			1	M52-3	
						ACSR					1	A9-1											1	M26-5	
																							1	M2-11	
A D D						2	#2	-																	
						ACSR																			
A D D						2	#2	-																	
						ACSR																			
A D D				1	#2																				
				TRI																					
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>					<b>BY</b>	<b>LOCATION-</b>					<b>EEE, LLC</b>					<b>RPSU - AKIAK, ALASKA</b>							
0	4/20/12	ISSUED FOR CONSTRUCTION						<b>DATE-</b>																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						<b>ENGINEER-</b> Greg Errico																	
								<b>APPROVED-</b>					<b>WORK ORDER NO.:</b> ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
RELOCATE	1	-																						Relocate service to Lot 10, from pole A6A, to this pole.	
	TRI																								
ADD				1	#2				Pole 19A	40/4		1	E1-3	1	F1-4P			1	J6	1	k11	1	M52-3		
							95'																		
REPEAT									Pole 19																
ADD									Pole 19-1	45/4	1	A1A										1	M52-3		
							159'																		
ADD																									
NO	DATE	REVISION					BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-										RPSU - AKIAK, ALASKA							
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico					EEE, LLC												
								APPROVED-										WORK ORDER NO.: ITB# 15113							



**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
E X I S T								Pole A7-1	-/-																
RETIRE						3	#2	148'			1	C1d													
						ACSR																			
RETIRE						3	#2	-																	
						ACSR																			
REPEAT								Pole 19-1																	
NO	DATE	REVISION					BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-						RPSU - AKIAK, ALASKA											
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER-	Greg Errico					EEE, LLC											
								APPROVED-						WORK ORDER NO.: ITB# 15113											

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
RELOCATE	1	-																						Relocate service to Lot 2 across the street, from pole C6B-1, to this pole.	
A D D							2	#2	159'	Pole 19-2	45/4	1	A1A	1	E1-3	1	F1-4P	1	G105-10	1	J6	1	K11	1	M52-3 1 M2-11
A D D							2	#2	-																
A D D				1	#2																				
NO	DATE	REVISION					BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-					EEE, LLC					RPSU - AKIAK, ALASKA							
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-										WORK ORDER NO.: ITB# 15113							



**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
RELOCATE	1	-	-																					Relocate service north to home across driveway, to pole 19-2C.	
	TRI																								
EXIST	1	-	-					Pole 19-2B (Old A7-2A)	-/-																
	TRI																								
RETIRE				1	-													1	J6	2	K11			Retire secondary to pole 18A (Old A8).	
				TRI			183'																		
ADD				1	#2													1	J10	1	KSE	1	M52-3		
				TRI			38'																		
REPEAT								Pole 19-2A (Old A7-2)																	
RELOCATE	1	-	-																					Relocate service north to home across driveway, to this pole.	
	TRI																								
ADD				1	#2			Pole 19-2C	40/5 (or larger)									1	J10	1	KSE	1	M52-3		
				TRI			39'															1	M2-11		
NO	DATE	REVISION					BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-						RPSU - AKIAK, ALASKA											
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER-	Greg Errico					EEE, LLC											
								APPROVED-						WORK ORDER NO.: ITB# 15113											



**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK	NO	SZ	BCK	NO	SZ																	
RELOCATE	1	-																						Relocate service to Lot 7, from pole 19-3A (Old C6), to this pole.	
ADD							2 #2	185'	Pole 19-3	45/4	1 A5 1 A2	1 E1-3	1 F1-4P	1 G105-10	1 J10	1 KSE	1 M52-3 1 M2-11 1 M26-5								
ADD							2 #2	-																	
ADD							2 #2	-																	
ADD				1	1/0																				
NO	DATE	REVISION					BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-					EEE, LLC					RPSU - AKIAK, ALASKA							
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-										WORK ORDER NO.: ITB# 15113							

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
RELOCATE	1	-																						Relocate service to Lot 7, to pole 19-3.	
EXIST	1	-						Pole 19-3A (Old C6)	-/-																
RETIRE				1	-	149'	3	#2	149'	1	C1d					3	J6	2	K11						
				TRI			ACSR			1	A9-1d														
RETIRE				1	-		3	#2																	
				TRI			ACSR																		
RETIRE				1	-		2	#2																	
				TRI			ACSR																		
RETIRE							2	#2																	
							ACSR																		
ADD				1	1/0	54'						1	E1-3	1	F1-4P		2	J6	1	K11	1	M52-3			
				TRI																					
ADD				1	1/0																				
				TRI																					
NO	DATE	REVISION					BY	LOCATION-					EEE, LLC					RPSU - AKIAK, ALASKA							
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-					WORK ORDER NO.: ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
RELOCATE	1	-	-																					Relocate second service to Lot 2, to pole 19-3C.	
EXIST	1	-	-					Pole 19-3B (Old C7)	-/-																
RETIRE				1	-					1	C1d			1	XFMR	1	J6	2	K11	1	M26-5				
RETIRE																								Span to pole C8.	
ADD				1	1/0											1	J5	1	K11	1	M52-3	1	M26-5		
ADD				1	1/0																				
RELOCATE	1	-	-																					Relocate second service to Lot 2, to this pole.	
ADD				1	1/0			Pole 19-3C	40/4			1	E1-3	1	F1-4P			1	J10	1	KSE	1	M52-3		
NO	DATE	REVISION					BY	LOCATION-					EEE, LLC					RPSU - AKIAK, ALASKA							
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-					WORK ORDER NO.: ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
REPEAT								Pole 19-3A (Old C6)																	
RELOCATE	2	-																						Relocate service north to Lot 1, to pole 19-3-1W. Relocate service southwest to Lot 2, to pole 19-3-2WA.	
EXIST								Pole C6A-1	-/-																
RETIRE						2	#2			1	A7d	1	E1-3	1	F1-4P	1	XFMR	2	J6	2	K11				
							ACSR	114'																	
RETIRE				1	-																				
RETIRE				1	-																				
	NO	DATE	REVISION				BY	LOCATION-																	
	0	4/20/12	ISSUED FOR CONSTRUCTION					DATE-																	
	1	2/18/15	ISSUED FOR CONSTR. - REV 1					ENGINEER- Greg Errico				EEE, LLC				RPSU - AKIAK, ALASKA									
								APPROVED-								WORK ORDER NO.: ITB# 15113									

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS	
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS		
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																		BCK SPN
RELOCATE	1	-	-																					Relocate service west to Lot 5, to pole 19-3-2WB.		
RELOCATE	TRI																									
RETIRE				1	-				Pole C6A-2	-/-								1	J6	1	K11					
RETIRE				TRI			218'																			
REPEAT																										
REPEAT									Pole 19-3																	
RELOCATE	1	-	-																					Relocate service to north to Lot 1, to this pole.		
RELOCATE	TRI																									
ADD								2	#2	153'	Pole 19-3-1W	45/4	1	A3	1	E1-3	1	F1-4P	1	G105-10	1	J10	1	KSE	1	M52-3
ADD								ACSR																1	M2-11	
ADD								2	#2																	
ADD								ACSR																		
ADD				1	#2																					
ADD				TRI																						
NO	DATE	REVISION					BY	LOCATION-	EEE, LLC					RPSU - AKIAK, ALASKA												
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																		
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																		
								APPROVED-						WORK ORDER NO.: ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR						LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE		SECONDARY		PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK	NO	SZ	BCK																	
TYPE	SPN	TYPE	SPN	TYPE	SPN	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS		
E X I S T	1	-						Pole 19-3 -1WA	-/-														
RETIRE			1	-			53'									1	J6	1	K11			Span to pole C6A-1.	
ADD			1	#2			56'									1	J6	1	K11	1	M52-3		
REPEAT								Pole 19-3-1W															
ADD						2	#2	192'	Pole 19-3-2W	45/4	1	A5	1	E1-3	1	F1-4P	1	G105-10	2	J6	1	M52-3	
						ACSR															1	M2-11	
ADD			1	1/0																			
			TRI																				
ADD			1	1/0																			
			TRI																				
NO	DATE	REVISION				BY	LOCATION-				EEE, LLC				RPSU - AKIAK, ALASKA								
0	4/20/12	ISSUED FOR CONSTRUCTION					DATE-																
1	2/18/15	ISSUED FOR CONSTR. - REV 1					ENGINEER- Greg Errico																
							APPROVED-				WORK ORDER NO.: ITB# 15113												



**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK	NO	SZ	BCK	NO	SZ																	
E X I S T	1	-						SVCs south of Pole -2WB												1	K16				
RETIRE																				2	K16			Retire daisy-chained service fed from first.	
A D D	1	#2	35'																	1	K16			Provide separate service to second weatherhead.	
REPEAT								Pole 19-3A (Old C6)																	
NO	DATE	REVISION					BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-						RPSU - AKIAK, ALASKA											
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER-	Greg Errico					EEE, LLC											
								APPROVED-						WORK ORDER NO.: ITB# 15113											

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR							LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS		
	SERVICE			SECONDARY			PRIMARY			NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS					
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO															SZ	BCK SPN			
E X I S T																										
RETIRE				1	-	171'	2	#2	171'					1	A9-1d			1	XFMR	4	J6					
RETIRE				1	-	-	2	#2	-																	
RETIRE				1	-	-																				
RETIRE				1	-	-																				
RELOCATE	1	-	-																							Relocate service to pole 19-4B.
E X I S T																										
RETIRE				1	-	84'												1	J6	1	K11					
NO		DATE		REVISION				BY		LOCATION-				EEE, LLC				RPSU - AKIAK, ALASKA				WORK ORDER NO.: ITB# 15113				
0		4/20/12		ISSUED FOR CONSTRUCTION						DATE-																
1		2/18/15		ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																
										APPROVED-																



**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR									LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS	
	SERVICE			SECONDARY			PRIMARY					NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS		
	NO	SZ	BCK	NO	SZ	BCK	NO	SZ	BCK																		
TYPE	SPN	TYPE	SPN	TYPE	SPN	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS				
E X I S T										Pole C4	-/-																
RETIRE				1	-							1	A9-1d							1	J6				1	M26-5	
							124'																				
RETIRE																											
RETIRE																											
RELOCATE	2	-																								Relocate service north to AK National Guard, to pole 19-5. Relocate service southwest to Lot 2, to pole 19-4B.	
E X I S T										Pole C3	-/-																
RETIRE												1	A9-1d							1	XFMR	2	J6	2	k11		
RETIRE				1	-																						
RETIRE				1	-																						
NO	DATE	REVISION						BY	LOCATION-	EEE, LLC						RPSU - AKIAK, ALASKA											
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																			
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																			
								APPROVED-							WORK ORDER NO.: ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR						LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE		SECONDARY		PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK	NO	SZ	BCK																	
TYPE	SPN	TYPE	SPN	TYPE	SPN	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS		
RELOCATE	2	-																				Relocate services to pole 19-5B.	
	TRI																						
EXIST							Pole C3A	-/-															
RETIRE			1	-												1	J6	1	K11				
			TRI		89'																		
REPEAT							Pole C3																
EXIST	1	-					Pole 19-5A (Old C2)	-/-															
	TRI																						
RETIRE			1	-		2	#2		1	A7d	1	E1-3	1	F1-4P	1	XFMR	1	J6	1	K11			
			TRI		125'	ACSR	125'																
ADD			1	1/0							1	E1-3	1	F1-4P			1	J6	1	K11	1	M52-3	
			TRI																			Raise and re-attach existing service to un-metered building, but do not connect it to new secondary.	
NO	DATE	REVISION				BY	LOCATION-						RPSU - AKIAK, ALASKA										
0	4/20/12	ISSUED FOR CONSTRUCTION					DATE-	EEE, LLC															
1	2/18/15	ISSUED FOR CONSTR. - REV 1					ENGINEER-	Greg Errico															
							APPROVED-						WORK ORDER NO.: ITB# 15113										



**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
A D D	1	#2		1	1/0				Pole 19-4A	40/4		1	E1-3	1	F1-4P			1	J6	1	K11	1	M52-3		
E X I S T									Corp. Store																
R E T I R E	1	#2																						Retire service to Corp. Store.	
A D D	1	#2																						Provide new service to Corp. Store.	
R E P E A T									Pole 9-4																
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>					<b>BY</b>	<b>LOCATION-</b>					<b>EEE, LLC</b>					<b>RPSU - AKIAK, ALASKA</b>							
0	4/20/12	ISSUED FOR CONSTRUCTION						<b>DATE-</b>																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						<b>ENGINEER- Greg Errico</b>																	
								<b>APPROVED-</b>					<b>WORK ORDER NO.: ITB# 15113</b>												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
RELOCATE	2	-	-																					Relocate service to Lot 3, to this pole. Relocate west service on Lot 2, to this pole.	
ADD				1	1/0						1	E1-3	1	F1-4P				1	J6	1	K10	1	M52-3		
								Pole 19-4B	40/4																
REPEAT								Pole 9-4																	
RELOCATE	1	-	-																					Relocate service north AK National Guard, to this pole.	
ADD										1	A7-1	1	E1-3	1	F1-4P	1	G136-10	2	J6	1	K11	1	M52-3		
								Pole 19-5	45/4														1	M2-11	
ADD				1	#2																				
ADD				1	1/0																			Frontspan to pole 19-5A	
NO	DATE	REVISION					BY	LOCATION-					EEE, LLC					RPSU - AKIAK, ALASKA							
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-					WORK ORDER NO.: ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK	NO	SZ	BCK	NO	SZ																	
TYPE	SPN		TYPE	SPN		TYPE	SPN																		
RELOCATE	2	-																					Relocate service from pole C3A, to this pole.		
ADD			1	#2			80'		Pole 19-5B	40/5 (or larger)		1	E1-3	1	F1-4P			1	J10	1	K11	1	M52-3		
REPEAT									Pole A7																
RETIRE						3	#2	144'	Pole A7A-1	-/-		1	C1d												
							ACSR																		
RETIRE						3	#2	-																	
							ACSR																		
NO	DATE	REVISION					BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico					EEE, LLC					RPSU - AKIAK, ALASKA							
								APPROVED-										WORK ORDER NO.: ITB# 15113							

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK	NO	SZ	BCK	NO	SZ																	
TYPE	SPN	TYPE	SPN	TYPE	SPN	TYPE	SPN	TYPE	SPN	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS		
RETIRE						3	#2		141'	Pole A7A-2	-/-	1	C8d	2	E1-3	2	F1-4P							Retire both poles and electrical appurtenances.	
RETIRE						2	#2		-		-/-														
EXIST	1	-								Consumer Owned Pole 82	-/-			1	E1-3	1	F1-4P			2	UM5				
EXIST	2	-																							
RETIRE						3	#2		-			1	C7d					1	XFMR						
ADD	1	1/0																		1	K11				
		TRI																		1	KSE				
NO	DATE	REVISION					BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-					EEE, LLC					RPSU - AKIAK, ALASKA							
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-										WORK ORDER NO.: ITB# 15113							

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK	NO	SZ	BCK	NO	SZ																	
REPEAT								Pole 19																	
A D D							2 #2 ACSR	131'	Pole 19-1N	45/4	1 A1A											1 M52-3			
A D D							2 #2 ACSR	-																	
A D D	1	1/0					2 #2 ACSR	195'	Pole 19-2N	45/4	1 A5	1 E1-3	1 F1-4P	1 G105-10				1 K11			1 M52-3 1 M2-11	Provide service to consumer owned pole.			
NO	DATE	REVISION					BY	LOCATION-					EEE, LLC					RPSU - AKIAK, ALASKA							
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-					WORK ORDER NO.: ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
REPEAT								Pole A7																	
EXIST								Pole A6	-/-																
RELOCATE	1	-																						Relocate service to Lot , to pole 19A.	
RETIRE						2	#2			1	A9-1d				1	XFMR	1	J6	1	K11					
							ACSR	202'																	
RETIRE						2	#2																		
							ACSR	-																	
RETIRE				1	-																				
							TRI																		
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>					<b>BY</b>	<b>LOCATION-</b>					<b>EEE, LLC</b>					<b>RPSU - AKIAK, ALASKA</b>							
0	4/20/12	ISSUED FOR CONSTRUCTION						<b>DATE-</b>																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						<b>ENGINEER-</b> Greg Errico																	
								<b>APPROVED-</b>					<b>WORK ORDER NO.:</b> ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
E X I S T																									
RELOCATE	2	-																							Relocate service to Lot 4, to pole 19. Relocate service to Lot 3, to pole 21.
RETIRE				1	-			61'									1	J6	2	K11					
REPEAT																									
E X I S T									Pole A6																
E X I S T									Pole A5	-/-															
RETIRE							2	#2			1	A9-1d	1	E1-3	1	F1-4P									
RETIRE								ACSR		198'															
RETIRE							2	#2																	
								ACSR																	
NO	DATE	REVISION					BY	LOCATION-					EEE, LLC					RPSU - AKIAK, ALASKA							
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-					WORK ORDER NO.: ITB# 15113												

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
RELOCATE	2	-																						Relocate service to Lot 6, to pole 22D. Relocate service to Lot 5, to pole 22E.	
	TRI																								
EXIST								Pole A4	-/-																
RETIRE						2	#2			1	A7d			1	XFMR	1	J6	2	K11						
						ACSR		152'																	
RETIRE				1	-																				
				TRI																					
RELOCATE	2	-																						Relocate service to Lot 2, to pole 21. Relocate service to Lot 1, to pole 22A.	
	TRI																								
EXIST								Pole A4A-1	-/-																
RETIRE				1	-											1	J6	2	K11						
				TRI		42'																			
NO	DATE	REVISION					BY	LOCATION-					EEE, LLC					RPSU - AKIAK, ALASKA							
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-					WORK ORDER NO.: ITB# 15113												



**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
RELOCATE	1	-																						Relocate service to home, north of Lot 1, to pole 22C.	
	TRI																								
EXIST								Tree																	
RETIRE	1	-																							
	TRI	153'																							
REPEAT								Pole 19																	
NO	DATE	REVISION					BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico					EEE, LLC					RPSU - AKIAK, ALASKA							
								APPROVED-										WORK ORDER NO.: ITB# 15113							

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
A D D						2	#2	169'	Pole 20	45/4	1	A1A										1	M52-3		
A D D						2	#2	-																	
RELOCATE	2	-																						Relocate services to homes on Lots 2 and 3, to this pole.	
A D D						2	#2	171'	Pole 21	45/4	1	A1A	1	E1-3	1	F1-4P			1	J6	1	K11	1	M52-3	
A D D				1	1/0		2	#2																	
NO	DATE	REVISION					BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-										RPSU - AKIAK, ALASKA							
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico					EEE, LLC												
								APPROVED-										WORK ORDER NO.: ITB# 15113							

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS	
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS		
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																		BCK SPN
A D D				1	1/0		2	#2		121'	121'	Pole 22	45/4	1	A5			1	G105-10	4	J6			1	M52-3	
				TRI			ACSR																			
A D D				1	1/0																					
				TRI																						
A D D				1	1/0																					
				TRI																						
A D D				1	1/0																					
				TRI																						
A D D				1	1/0					78'		Pole 22F	40/4			1	E2-3	1	F1-4P			1	J6		1	M52-3
				TRI																						
<b>NO</b>	<b>DATE</b>	<b>REVISION</b>					<b>BY</b>	<b>LOCATION-</b>					<b>EEE, LLC</b>					<b>RPSU - AKIAK, ALASKA</b>								
0	4/20/12	ISSUED FOR CONSTRUCTION						<b>DATE-</b>																		
1	2/18/15	ISSUED FOR CONSTR. - REV 1						<b>ENGINEER-</b> Greg Errico																		
								<b>APPROVED-</b>					<b>WORK ORDER NO.:</b> ITB# 15113													

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
REPEAT								Pole 22																	
RELOCATE	1	-																						Relocate service to Lot 6, to this pole.	
ADD				1	1/0		40'	Pole 22D	40/5 (or larger)							1	J6	1	KSE	1	M52-3				
ADD				1	#2																				
RELOCATE	1	-																						Relocate service to Lot 5, to this pole.	
ADD				1	#2		60'	Pole 22E	40/5 (or larger)							1	J6	1	K11	1	M52-3				
NO	DATE	REVISION					BY	LOCATION-	EEE, LLC					RPSU - AKIAK, ALASKA											
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-	WORK ORDER NO.:					ITB# 15113											

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK SPN	NO	SZ	BCK SPN	NO	SZ																	
REPEAT								Pole 22																	
RELOCATE	1	-																						Relocate service to Lot 1, to this pole.	
ADD				1	1/0		75'	Pole 22A	40/4							2	J6		1	K11		1	M52-3		
ADD				1	1/0		-																		
ADD				1	1/0		218'	Pole 22B	40/4							2	J6					1	M52-3		
ADD				1	1/0		-																		
NO	DATE	REVISION					BY	LOCATION-	EEE, LLC						RPSU - AKIAK, ALASKA										
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico																	
								APPROVED-	WORK ORDER NO.: ITB# 15113																

**STAKING SHEET**

EXIST RETIRE ADD REPEAT	CONDUCTOR								LOCATION	HEIGHT AND CLASS	PRIMARY ASSEMBLY		GUYS (E)		ANCHORS (F)		TRANS- FORMERS (G)		SECONDARY (J)		SERVICE (K)		MISC (M)		REMARKS
	SERVICE			SECONDARY			PRIMARY				NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	NO	UNITS	
	NO	SZ	BCK	NO	SZ	BCK	NO	SZ																	
TYPE	SPN		TYPE	SPN		TYPE	SPN																		
RELOCATE	1	-																					Relocate service to home, north of Lot 1, to this pole.		
ADD				1	1/0				Pole 22C	40/4		1	E1-3	1	F1-4P			1	J6	1	K11	1	M52-3		
NO	DATE	REVISION					BY	LOCATION-																	
0	4/20/12	ISSUED FOR CONSTRUCTION						DATE-																	
1	2/18/15	ISSUED FOR CONSTR. - REV 1						ENGINEER- Greg Errico					EEE, LLC												
								APPROVED-					RPSU - AKIAK, ALASKA												
											WORK ORDER NO.: ITB# 15113														